



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-01	Hallway, Outside Multi-Purpose Room, Left of Girl's Bathroom, Bottle Fill, Water Cooler	BT	9:37 AM	5	ND <sup>3</sup>	Y	First Draw
Mitchell-02	Room 3, Bubbler	C	9:17 AM	5	ND	N	First Draw
Mitchell-03	Room 3, Faucet	C	9:18 AM	5	ND	Y	First Draw
Mitchell-04	Room 4, Bubbler	C	9:19 AM	5	ND	N	First Draw
Mitchell-05	Hallway, New Addition, Right Water Cooler	WC	8:50 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Mitchell-06	Room 8, Bubbler	C	10:40 AM	5	ND	N	First Draw
Mitchell-07	Room 9, Right Sink Faucet	C	10:34 AM	5	ND	Y	First Draw
Mitchell-08	Teacher's Lounge Faucet	KF	9:50 AM	5	ND	Y	First Draw
Mitchell-09	Hallway Outside Gym, Bottle Fill, Water Cooler	BT	9:53 AM	5	ND	Y	First Draw
Mitchell-10	Room 15, Single Bubbler	B	10:00 AM	5	ND	N	First Draw
Mitchell-11	Room 19, Single Bubbler	B	8:43 AM	5	ND	N	First Draw
Mitchell-12	Hallway, New Addition, Left Water Cooler	WC	8:51 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Mitchell-13	Room 4, Faucet	C	9:20 AM	5	ND	Y	First Draw
Mitchell-14	Hallway, Outside Multi-Purpose Room, Left of Girl's Bathroom, Bottle Fill	BT	9:38 AM	5	ND	Y	First Draw
Mitchell-15	Room 8, Faucet	C	10:37 AM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-16	Room 9, Right Sink Bubbler	C	10:36 AM	5	ND	N	First Draw
Mitchell-17	Hallway, Outside Gym, Bottle Fill	BT	9:55 AM	5	ND	Y	First Draw
Mitchell-18	Room 5, Bubbler	C	9:25 AM	5	ND	N	First Draw
Mitchell-19	Room 5, Faucet	C	9:26 AM	5	ND	Y	First Draw
Mitchell-20	Room 2, Right Sink Bubbler	C	9:21 AM	5	ND	N	First Draw
Mitchell-21	Room 2, Right Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-22	Room 2, Middle Sink Bubbler	C	9:22 AM	5	ND	N	First Draw
Mitchell-23	Room 2, Middle Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-24	Room 2, Left Sink Faucet	C	9:23 AM	5	ND	Y	First Draw
Mitchell-25	Room 2, Left Sink Bubbler	C	9:24 AM	5	ND	N	First Draw
Mitchell-26	Room 1, Right Sink Bubbler	C	9:27 AM	5	ND	N	First Draw
Mitchell-27	Room 1, Right Sink Faucet	C	9:28 AM	5	ND	Y	First Draw
Mitchell-28	Room 1, Middle Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-29	Room 1, Middle Sink Bubbler	C	9:30 AM	5	ND	N	First Draw
Mitchell-30	Room 1, Left Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-31	Room 1, Left Sink Bubbler	C	9:32 AM	5	ND	N	First Draw
Mitchell-32	Room 6, Right Sink Bubbler	C	9:33 AM	5	ND	N	First Draw
Mitchell-33	Room 6, Right Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-34	Room 6, Middle Sink Faucet	C	Not Sampled				Did not sample- Only Hot Water
Mitchell-35	Room 6, Middle Sink Bubbler	C	9:34 AM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-36	Room 6, Left Sink Bubblers	C	9:35 AM	5	ND	N	First Draw
Mitchell-37	Room 6, Left Sink Faucet	C	9:36 AM	5	ND	Y	First Draw
Mitchell-38	Room 9, Left Sink Bubblers	C	10:30 AM	5	ND	N	First Draw
Mitchell-39	Room 9, Left Sink Faucet	C	10:32 AM	5	ND	Y	First Draw
Mitchell-40	Room 10, Right Sink Bubblers	C	10:20 AM	5	ND	N	First Draw
Mitchell-41	Room 10, Right Sink Faucet	C	10:21 AM	5	ND	Y	First Draw
Mitchell-42	Room 10 Left Sink Faucet	C	10:22 AM	5	ND	Y	First Draw
Mitchell-43	Room 10, Left Sink Bubblers	C	10:23 AM	5	ND	N	First Draw
Mitchell-44	Room 14, Sink Bubblers	C	9:56 AM	5	1	N	First Draw
Mitchell-45	Room 14, Sink Faucet	C	9:57 AM	5	1	Y	First Draw
Mitchell-46	Room 14, Single Bubblers	B	9:58 AM	5	ND	N	First Draw
Mitchell-47	Room 15, Sink Bubblers	C	10:02 AM	5	ND	N	First Draw
Mitchell-48	Room 15, Sink Faucet	C	10:04 AM	5	ND	Y	First Draw
Mitchell-49	Room 16, Sink Bubblers	C	10:10 AM	5	ND	N	First Draw
Mitchell-50	Room 16, Sink Faucet	C	10:11 AM	5	ND	Y	First Draw
Mitchell-51	Room 16, Single Bubblers	B	10:12 AM	5	2	N	First Draw
Mitchell-52	Room 20, Sink Bubblers	C	8:30 AM	5	ND	N	First Draw
Mitchell-53	Room 20, Sink Faucet	C	8:31 AM	5	ND	Y	First Draw
Mitchell-54	Room 20, Single Bubblers	B	8:33 AM	5	1	N	First Draw
Mitchell-55	Room 19, Sink Bubblers	C	8:44 AM	5	ND	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes	
Mitchell-56	Room 19, Sink Faucet	C	8:45 AM	5	ND	Y	First Draw	
Mitchell-57	Kitchen, 3-Compartment Sink, Left Faucet	KF	9:45 AM	5	ND	Y	First Draw	
Mitchell-58	Kitchen, 3-Compartment Sink, Right Faucet	KF	9:46 AM	5	ND	Y	First Draw	
Mitchell-59	Hallway Outside Room 6, Bubblers - OUT OF SERVICE	B	Not Sampled					Did not sample-Out of Service
Mitchell-60	Multi-Purpose Room, Right Water Cooler	WC	9:40 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.	
Mitchell-61	Multi-Purpose Room, Left Water Cooler	WC	9:41 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.	
Mitchell-62	Room 25, Faucet	C	9:14 AM	5	ND	Y	First Draw	
Mitchell-63	Room 25, Bubblers	C	9:16 AM	5	ND	N	First Draw	
Mitchell-64	Room 26, Faucet	C	9:06 AM	5	ND	Y	First Draw	
Mitchell-65	Room 26, Bubblers	C	9:08 AM	5	ND	N	First Draw	
Mitchell-66	Room 22, Bubblers	C	9:00 AM	5	ND	N	First Draw	
Mitchell-67	Room 22, Faucet	C	9:02 AM	5	ND	Y	First Draw	
Mitchell-68	Room 23, Bubblers	C	9:07 AM	5	ND	N	First Draw	
Mitchell-69	Room 23, Faucet	C	9:11 AM	5	ND	Y	First Draw	
Mitchell-70	Room 24, Bubblers	C	9:10 AM	5	ND	N	First Draw	
Mitchell-71	Room 24, Faucet	C	9:12 AM	5	ND	Y	First Draw	

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-72	Room 21, Faucet	C	8:56 AM	5	ND	Y	First Draw
Mitchell-73	Room 21, Bubbler	C	8:55 AM	5	ND	N	First Draw
Mitchell-74	Portable, Right Water Cooler	WC	8:15 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.
Mitchell-75	Portable, Left Water Cooler	WC	8:16 AM	5	ND	N	First Draw. Water cooler was reviewed against the EPA Fact Sheet to determine that it is not a lead lined.

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-21	Room 2, Right Sink Faucet	C	12:42 PM	5	2	Y	First Draw. Fixed Location
Mitchell-23	Room 2, Middle Sink Faucet	C	12:45 PM	5	2	Y	First Draw. Fixed Location
Mitchell-28	Room 1, Middle Sink Faucet	C	12:39 PM	5	4	Y	First Draw. Fixed Location
Mitchell-30	Room 1, Left Sink Faucet	C	12:40 PM	5	2	Y	First Draw. Fixed Location
Mitchell-33	Room 6, Right Sink Faucet	C	12:35 PM	5	2	Y	First Draw. Fixed Location
Mitchell-34	Room 6, Middle Sink Faucet	C	12:35 PM	5	3	Y	First Draw. Fixed Location

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell-12	Hallway, New Addition, Left Single Bottle Fill	BF	1:18 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-61	Multi-Purpose Room, Hydration Station, Water Cooler	BF	1:10 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-75	Portable, Hallway, Hydration Station, Water Cooler	BF	1:30 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-76	Portable, Hallway, Hydration Station, Bottle Fill	BF	1:30 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-77	Hallway, Outside Art Room, Hydration Station, Water Cooler	BF	1:15 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-78	Hallway, Outside Art Room, Hydration Station, Bottle Fill	BF	1:15 PM	5	ND	N	First Draw. New Hydration Station.
Mitchell-79	Multi-Purpose Room, Hydration Station, Bottle Fill	BF	1:10 PM	5	ND	N	First Draw. New Hydration Station.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb