



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Pathways For Success							
Date of Sampling: 10/27/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 04	Hallway, Outside Room 402, Bubbler	B	8:40 AM	5	7	N	First Draw. Low Flow.

Pathways For Success							
Date of Sampling: 11/10/2018							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 12	3-Compartment Sink, Kitchen Sprayer	KS	1:35 PM	5	6	N	First Draw

Pathways For Success							
Date of Sampling: 01/12/2019							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 10	Media Center, Work Room, Faucet	F	3:23 PM	5	100	Y	Follow-up first draw following replacement.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861

Pathways For Success							
Date of Sampling: 01/31/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 04	Hallway, Outside Room 402, Bubbler	Replaced with a Hydration Station					
Pathways - 12	3-Compartment Sink, Kitchen Sprayer	Placed Non-Potable-Do Not Use for Food Prep Sign					
Pathways - 10A	Media Center, Work Room, Faucet	F	10:49 AM	5	5	Y	Follow-up first draw following replacement.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb