



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Ann Arbor STEAM at Northside							
Date of Sampling: 11/3/2018							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM -10	Room MS-3, Faucet	F	3:54 PM	5	6	Y	First Draw
STEAM -26	Room MS-1, Faucet	F	3:50 PM	5	45	Y	First Draw
STEAM -45	Room 303, Faucet	C	4:26 PM	5	31	Y	First Draw. Corrosion on Aerator.
STEAM -51	Room 203, Faucet	C	4:30 PM	5	11	Y	First Draw. Corrosion on Aerator.
STEAM -53	Room 202, Faucet	C	4:32 PM	5	6	Y	First Draw

Ann Arbor STEAM at Northside							
Date of Sampling: 12/22/2018							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM-10A	Room MS-3, Faucet	F	10:05 AM	5	5	Y	Follow-Up First Draw Following Replacement. Discolored water, slightly brown observed.
STEAM -26A	Room MS-1, Faucet	F	10:00 AM	5	6	Y	Follow-Up First Draw Following Replacement
STEAM -45A	Room 303, Faucet	C	8:20 AM	5	6	Y	Follow-Up First Draw Following Replacement
STEAM -51A	Room 203, Faucet	C	8:25 AM	5	8	Y	Follow-Up First Draw Following Replacement
STEAM -53A	Room 202, Faucet	C	8:30 AM	5	7	Y	Follow-Up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Ann Arbor STEAM at Northside							
Date of Sampling: 01/12/2019							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM -26B	Room MS-1, Faucet	F	12:56 PM	5	9	Y	2nd Follow-Up First Draw Following Replacement
STEAM -45B	Room 303, Faucet	C	12:39 PM	5	8	Y	2nd Follow-Up First Draw Following Replacement
STEAM -51B	Room 203, Faucet	C	12:40 PM	5	12	Y	2nd Follow-Up First Draw Following Replacement
STEAM -53B	Room 202, Faucet	C	12:41 PM	5	7	Y	2nd Follow-Up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Ann Arbor STEAM at Northside

Date of Sampling: 02/02/2019

Sampler: Jenna Sendra

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM -26C	Room MS-1, Faucet	F	11:42 AM	5	3	Y	3rd Follow-Up First Draw Following Replacement. Filter added.
STEAM -45C	Room 303, Faucet	C	11:32 AM	5	2	Y	3rd Follow-Up First Draw Following Replacement. Filter added.
STEAM -51C	Room 203, Faucet	C	11:32 AM	5	ND	Y	3rd Follow-Up First Draw Following Replacement. Filter added.
STEAM-53C	Room 202, Faucet	C	11:35 AM	5	ND	Y	3rd Follow-Up First Draw Following Replacement. Filter added.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb