



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861**

Scarlett Middle School							
Date of Sampling: 01/21/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-01	Hallway, Adjacent to Band Room 138 & Stage, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-02	Girl's Locker Room, Bubbler	B	10:15 PM	5	2		First Draw
Scarlett-03	Boy's Locker Room, Bubbler	B	10:17 PM	5	1		Corrosion on Mouthpiece, First Draw.
Scarlett-04	OPEN NUMBER						
Scarlett-05	Kitchen, 3 Compartment Sink	KF	10:05 AM	5	5		First Draw
Scarlett-06	OPEN NUMBER						
Scarlett-07	OPEN NUMBER						
Scarlett-08	OPEN NUMBER						
Scarlett-09	Staff Kitchen Faucet in Cafeteria	KF	10:04 AM	5	1		First Draw
Scarlett-10	Hallway, Outside Main Office by Stairway, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-11	Main Office Wing, Mailroom Faucet	F	9:53 AM	5	ND <sup>3</sup>	Y	First Draw
Scarlett-12	Hallway, Outside Room 130, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-13	Hallway, Outside Room 124, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-14	Room 137, Faucet	F	10:29 AM	5	4	Y	First Draw
Scarlett-15	OPEN NUMBER						

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861**

Scarlett Middle School							
Date of Sampling: 01/21/2019							
Sampler: Steven Ripley							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-16	Hallway, Outside Room 215, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-17	Room 201, Faucet	F	10:27 AM	5	2	Y	First Draw
Scarlett-18	Room 228, Faucet	F	10:34 AM	5	4	Y	First Draw
Scarlett-19	Hallway, Outside of Room 228, Hydration Station Bottle Fill	BT	Not Sampled.				Out of Service.
Scarlett-20	Hallway, Outside of Room 228, Hydration Station Water Cooler	BT	Not Sampled.				Out of Service.
Scarlett-21	Auxiliary Gym, Single Bubbler	B	10:30 AM	5	1		Corrosion on Mouthpiece, First Draw.
Scarlett-22	OPEN NUMBER						
Scarlett-23	Hallway, Outside Room 144, Bubbler	B	Not Sampled.				Scheduled for replacement with a Hydration Station.
Scarlett-24	Cafeteria, Hydration Station, Water Cooler	WC	9:59 AM	5	ND		First Draw.
Scarlett-25	Cafeteria, Hydration Station, Bottle Fill	BT	9:59 AM	5	ND		First Draw
Scarlett-26	Cafeteria, Single Water Cooler	WC	10:00 AM	5	ND		First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE180861

<b>Scarlett Middle School</b>							
<b>Date of Sampling: 01/21/2019</b>							
<b>Sampler: Steven Ripley</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested