



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Thurston Elementary School

Date of Sampling: 11/10/2018

Sampler: Lindsey Eveleth

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-27	Room 21, Bubblers	C	3:15 PM	5	6	N	First Draw
Thurston-43	Main Office Kitchenette, Faucet	F	4:12 PM	5	34	Y	First Draw

Thurston Elementary School

Date of Sampling: 12/22/2018

Sampler: Gary Bosh

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-27A	Room 21, Bubblers	C	7:57 AM	5	8	N	Follow-Up First Draw Following Replacement
Thurston-43A	Main Office Kitchenette, Faucet	F	7:54 AM	5	7	Y	Follow-Up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE180861**

Thurston Elementary School							
Date of Sampling: 01/12/2019							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-27B	Room 21, Bubbler	C	1:21 PM	5	4	N	2nd Follow-Up First Draw Following Replacement
Thurston-43B	Main Office Kitchenette, Faucet	F	1:16 PM	5	21	Y	2nd Follow-Up First Draw Following Replacement
Thurston Elementary School							
Date of Sampling: 01/31/2019							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-43C	Main Office Kitchenette, Faucet	F	10:01 AM	5	2	Y	3rd Follow-Up First Draw Following Replacement. Added Filter

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested