



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Thurston Elementary School							
Date of Sampling: 11/10/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-01	Hallway, in Front of Custodian Lounge, Water Cooler	WC	2:00 PM	5	ND ³	N	First Draw. Deterioration around mouthpiece.
Thurston-02	Teachers Lounge Kitchenette, Two Compartment Sink	KF	1:57 PM	5	ND	Y	First Draw
Thurston-03	Hallway, Left of Office, Left Single Water Cooler	WC	3:23 PM	5	ND	N	First Draw
Thurston-04	Hallway, to Left of Office, Bottle Fill Outlet	BF	3:26 PM	5	2	N	First Draw
Thurston-05	Hallway, Left of Multipurpose Room D103, Bottle Fill, Water Cooler Outlet	BF	3:28 PM	5	ND	N	First Draw
Thurston-06	Hallway, Left of Multipurpose Room D103, Right Single Water Cooler	WC	Not Sampled				No flow, Turned off. Did not sample.
Thurston-07	Room C2, Bubblers	C	4:03 PM	5	ND	N	First Draw. Corrosion and rust on mouthpiece.
Thurston-08	Room 3, Bubblers	C	3:57 PM	5	ND	N	First Draw
Thurston-09	Room 4, Bubblers	C	3:51 PM	5	ND	N	First Draw
Thurston-10	Room 8, Bubblers	C	2:09 PM	5	ND	N	First Draw
Thurston-11	Room 9, Bubblers	C	2:33 PM	5	1	N	First Draw. Low Flow.
Thurston-12	Room 10, Bubblers	C	2:37 PM	5	ND	N	First Draw
Thurston-13	Room 28, Bubblers	C	3:00 PM	5	2	N	First Draw
Thurston-14	Room 28, Faucet	C	3:02 PM	5	1	Y	First Draw
Thurston-15	Room 26, Bubblers	C	2:56 PM	5	2	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Thurston Elementary School							
Date of Sampling: 11/10/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-16	Room 26, Faucet	C	2:58 PM	5	ND	Y	First Draw
Thurston-17	Room 24, Bubblers	C	2:51 PM	5	3	N	First Draw
Thurston-18	Room 24, Faucet	C	2:54 PM	5	2	Y	First Draw
Thurston-19	Room 22, Bubblers	C	2:44 PM	5	1	N	First Draw
Thurston-20	Room 22, Faucet	C	2:46 PM	5	1	Y	First Draw
Thurston-21	Room 27, Bubblers	C	3:04 PM	5	3	N	First Draw
Thurston-22	Room 27, Faucet	C	3:06 PM	5	3	Y	First Draw
Thurston-23	Room 25, Bubblers	C	3:09 PM	5	3	N	First Draw
Thurston-24	Room 25, Faucet	C	3:11 PM	5	1	Y	First Draw
Thurston-25	Room 23, Bubblers	C	3:15 PM	5	2	N	First Draw
Thurston-26	Room 23, Faucet	C	3:17 PM	5	ND	Y	First Draw
Thurston-27	Room 21, Bubblers	C	3:15 PM	5	6	N	First Draw
Thurston-28	Room 21, Faucet	C	3:19 PM	5	2	Y	First Draw
Thurston-29	Hallway, Outside Rooms 22, Water Cooler	WC	2:48 PM	5	ND	N	First Draw
Thurston-30	Room 7, Bubblers	C	2:02PM	5	ND	N	First Draw
Thurston-31	Room 7, Faucet	C	2:04 PM	5	ND	Y	First Draw
Thurston-32	Room 8, Faucet	C	2:07 PM	5	ND	Y	First Draw
Thurston-33	Room K11, Bubblers	C	2:12 PM	5	4	N	First Draw
Thurston-34	Room K11, Faucet	C	2:14 PM	5	ND	Y	First Draw
Thurston-35	Room A101, Bubblers	C	2:17 PM	5	ND	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Thurston Elementary School							
Date of Sampling: 11/10/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-36	Room A101, Faucet	C	2:19 PM	5	ND	Y	First Draw
Thurston-37	Room A106, Bubbler	C	2:23 PM	5	ND	N	First Draw
Thurston-38	Room A106, Faucet	C	2:26 PM	5	ND	Y	First Draw
Thurston-39	Room K12, Bubbler	C	2:30 PM	5	1	N	First Draw
Thurston-40	Room K12, Faucet	C	2:32 PM	5	2	Y	First Draw
Thurston-41	Room 9, Faucet	C	2:34 PM	5	1	Y	First Draw
Thurston-42	Room 10, Faucet	C	2:39 PM	5	ND	Y	First Draw
Thurston-43	Main Office Kitchenette, Faucet	F	4:12 PM	5	34	Y	First Draw
Thurston-44	Room C1, Bubbler	C	4:07 PM	5	ND	N	First Draw
Thurston-45	Room C1, Faucet	C	4:09 PM	5	ND	Y	First Draw. Corrosion on aerator.
Thurston-46	Room C2, Faucet	C	4:01 PM	5	2	Y	First Draw
Thurston-47	Room 3, Faucet	C	3:58 PM	5	1	Y	First Draw
Thurston-48	Room 4, Faucet	C	3:53 PM	5	ND	Y	First Draw
Thurston-49	Room 5, Bubbler	C	3:44 PM	5	ND	N	First Draw
Thurston-50	Room 5, Faucet	C	3:46 PM	5	1	Y	First Draw. Corrosion around aerator.
Thurston-51	Room 6, Bubbler	C	3:39 PM	5	ND	N	First Draw
Thurston-52	Room 6, Faucet	C	3:41 PM	5	ND	Y	First Draw
Thurston-53	Hallway, to Left of Office, Bottle Fill Outlet	BT	3:25 PM	5	ND	N	First Draw
Thurston-54	Hallway, Left of Multipurpose Room D103, Bottle Fill Outlet	BT	3:30 PM	5	ND	N	First Draw
Thurston-55	Kitchen, 3-Compartment Sink, Right Faucet	KF	3:35 PM	5	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Lead Drinking Water Analysis
 Project Number: AE180861

Thurston Elementary School							
Date of Sampling: 11/10/2018							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Thurston-56	Kitchen, 3-Compartment Sink, Left Faucet	KF	3:33 PM	5	ND	Y	First Draw
Thurston-57	Portable, Left Water Cooler	WC	4:18 PM	5	ND	N	First Draw
Thurston-58	Portable, Right Water Cooler	WC	4:20 PM	5	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-drinking-water/table-regulated-drinking-water-contaminante>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested