



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Abbot Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-01	Hallway, Next to Gym, Across from Teacher's Lounge, Hydration Station, Water Cooler	BT	2:13 PM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Abbot-02	Office/Teachers Lounge, Kitchenette, Faucet	KF	2:21 PM	5	ND	Y	First Draw, Filtered.
Abbot-03	OPEN NUMBER						
Abbot-04	Room C-5, Single Bubbler						Not Functional During Sampling.
Abbot-05	Kitchen, 3-Compartment, Far Left Add on Faucet	KF	2:47 PM	5	ND	Y	First Draw, Filtered.
Abbot-06	Room B-1, Combination Sink, Faucet	C	2:38 PM	5	ND	Y	First Draw, Filtered.
Abbot-07	Room B-1, Combination Sink, Bubbler	C	2:39 PM	5	ND	N	First Draw, Filtered.
Abbot-08	Room D-2, Single Bubbler	B	3:40 PM	5	ND	N	First Draw, Filtered.
Abbot-09	Room D-3, Single Bubbler	B	3:37 PM	5	ND	N	First Draw, Filtered.
Abbot-10	Room D-4, Single Bubbler	B	3:34 PM	5	1	N	First Draw, Filtered.
Abbot-11	Room D-5, Single Bubbler						Not Functional During Sampling.
Abbot-12	Hallway, Next to Room C-8, Hydration Station, Water Cooler	BT	2:52 PM	5	ND	N	First Draw, Filtered.
Abbot-13	Hallway, Next to Gym, Across from Teacher's Lounge, Hydration Station, Bottle Fill	BT	2:14 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-are-drinking-water/table-regulated-drinking-water-contaminant>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Abbot Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-14	Multi Purpose Room, Hydration Station, Water Cooler	BT	2:32 PM	5	ND	N	First Draw, Filtered.
Abbot-15	Room D-6, Island Near Door, Combination Sink, Bubbler	C	3:23 PM	5	ND	N	First Draw, Filtered.
Abbot-16	Room D-7, Island Near Door, Combination Sink, Bubbler	C	3:20 PM	5	ND	N	First Draw, Filtered.
Abbot-17	D Hall Centrum, Hydration Station, Water Cooler	BT	3:44 PM	5	ND	N	First Draw, Filtered.
Abbot-18	D Hall Centrum, Hydration Station, Bottle Fill	BT	3:45 PM	5	ND	N	First Draw, Filtered.
Abbot-19	Room C-10, Single Sink Faucet	F	3:12 PM	5	ND	N	First Draw, Filtered.
Abbot-20	Multi Purpose Room, Hydration Station, Bottle Fill	BT	2:33 PM	5	ND	N	First Draw, Filtered.
Abbot-21	Room D-7, Island Near Door, Combination Sink, Faucet	C	3:21 PM	5	ND	Y	First Draw, Filtered.
Abbot-22	Room D-6, Corner of Room, Combination Sink, Bubbler	C	3:28 PM	5	8	N	First Draw, Filtered.
Abbot-23	Room D-6, Corner of Room, Combination Sink, Faucet	C	3:29 PM	5	19	Y	First Draw, Filtered.
Abbot-24	Room C-6, Single Bubbler	B	3:05 PM	5	ND	N	First Draw, Filtered.
Abbot-25	Room C-7, Single Bubbler	B	3:02 PM	5	ND	N	First Draw, Filtered.
Abbot-26	Room C-8, Single Bubbler	B	2:58 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Abbot Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Kellie Das							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-27	Hallway, Next to Room C-8, Hydration Station, Bottle Fill	BT	2:54 PM	5	ND	N	First Draw, Filtered.
Abbot-28	Office Workroom, Single Sink Faucet	F	2:24 PM	5	ND	N	First Draw, Filtered.
Abbot-29	Nurse's Clinic, Single Sink Faucet	F	2:27 PM	5	ND	N	First Draw, Filtered.
Abbot-30	Room A-3, Single Bubbler						Not Functional During Sampling.
Abbot-31	Room D-6, Island Near Door, Combination Sink, Bubbler	C	3:24 PM	5	ND	Y	First Draw, Filtered.
Abbot-32	Room A-5, Single Bubbler						Not Functional During Sampling.
Abbot-33	Room A-6, Single Bubbler						Not Functional During Sampling.
Abbot-34	Room A-7, Single Bubbler	B	1:57 PM	5	ND	N	First Draw, Filtered.
Abbot-35	Room A-8, Single Bubbler	B	2:00 PM	5	ND	N	First Draw, Filtered.
Abbot-36	A Hall Centrum, Hydration Station, Water Cooler	BT	1:32 PM	5	ND	N	First Draw, Filtered.
Abbot-37	Room A-10, Single Bubbler	B	2:05 PM	5	ND	N	First Draw, Filtered.
Abbot-38	A Hall Centrum, Hydration Station, Bottle Fill	BT	1:33 PM	5	ND	N	First Draw, Filtered.
Abbot-39	Hallway, Outside Room B-2, Hydration Station, Water Cooler	BT	2:42 PM	5	ND	N	First Draw, Filtered.
Abbot-40	Hallway, Outside Room B-2, Hydration Station, Bottle Fill	BT	2:43 PM	5	ND	N	First Draw, Filtered.
Abbot-41	Room A-4, Single Bubbler	B	1:42 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
 Lead Drinking Water Analysis  
 Project Number: AE190030

<b>Abbot Elementary School</b>							
<b>Date of Sampling: 12/21/2019</b>							
<b>Sampler: Kellie Das</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-42	C Hall Centrum, Single Sink	F	2:55 PM	5	ND	Y	First Draw, Filtered.
Abbot-43	A Hall Centrum, Single Sink	F	1:34 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Abbot Elementary School							
Date of Sampling: 1/3/2020							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-04	Room C-5, Single Bubblers	B	1:20 PM	5	ND	N	First Draw, Filtered.
Abbot-11	Room D-5, Single Bubblers	B	1:30 PM	5	ND	N	First Draw, Filtered.
Abbot-30	Room A-3, Single Bubblers	B	1:45 PM	5	ND	N	First Draw, Filtered.
Abbot-32	Room A-5, Single Bubblers	B	1:55 PM	5	ND	N	First Draw, Filtered.
Abbot-33	Room A-6, Single Bubblers	B	2:00 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Abbot Elementary School							
Date of Sampling: N/A							
Sampler: N/A							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot-22	Room D-6, Corner of Room, Combination Sink, Bubbler	C	N/A	5	N/A	N	Bubbler Capped and Permanently Removed from Service
Abbot-23	Room D-6, Corner of Room, Combination Sink, Faucet	C	N/A	5	N/A	Y	Faucet Replaced and Determined to be Nonpotable, No Drinking Signage Placed.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb