



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Angell Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-01	Room C-108, Combination Sink, Faucet	C	10:22 AM	5	ND ³	Y	First Draw, Filtered.
Angell-02	Room C-147, Combination Sink, Bubbler	C	10:40 AM	5	ND	N	First Draw, Filtered.
Angell-03	Main Office, Clinic Single Sink	F	10:13 AM	5	4	Y	First Draw, Filtered.
Angell-04	Hallway, Outside Main Office, Hydration Station, Water Cooler	BT	10:08 AM	5	ND	N	First Draw, Filtered.
Angell-05	Kitchen, 3-Compartment, Add On Far Right Faucet	KF	11:28 AM	5	ND	Y	First Draw, Filtered.
Angell-06	Room C-123, Combination Sink, Bubbler	C	9:56 AM	5	ND	Y	First Draw, Filtered.
Angell-07	Room C-119, Combination Sink, Bubbler	C	10:04 AM	5	ND	Y	First Draw, Filtered.
Angell-08	Room C-221, Combination Sink, Bubbler	C	11:11 AM	5	ND	N	First Draw, Filtered.
Angell-09	Room C-217, Combination Sink, Bubbler	C	11:19 AM	5	ND	Y	First Draw, Filtered.
Angell-10	Room C-207, Combination Sink, Bubbler	C	10:54 AM	5	ND	Y	First Draw, Filtered.
Angell-11	Room C-212, Combination Sink, Bubbler	C	11:01 AM	5	ND	N	First Draw, Filtered.
Angell-12	Room C-101, Combination Sink, Bubbler	C	10:17 AM	5	ND	N	First Draw, Filtered.
Angell-13	OPEN NUMBER						

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-are-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Angell Elementary School

Date of Sampling: 1/11/2020

Sampler: Alec Staber

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-14	Room C-123, Combination Sink, Faucet	C	9:57 AM	5	ND	Y	First Draw, Filtered.
Angell-15	Room C-121, Combination Sink, Bubbler	C	10:00 AM	5	ND	N	First Draw, Filtered.
Angell-16	Room C-121, Combination Sink, Faucet	C	10:01 AM	5	ND	Y	First Draw, Filtered.
Angell-17	Room C-119, Combination Sink, Faucet	C	10:05 AM	5	ND	Y	First Draw, Filtered.
Angell-18	Room C-108, Combination Sink, Bubbler	C	10:23 AM	5	ND	N	First Draw, Filtered.
Angell-19	Room C-110, Combination Sink, Bubbler	C	10:30 AM	5	ND	N	First Draw, Filtered.
Angell-20	Room C-110, Combination Sink, Faucet	C	10:31 AM	5	ND	Y	First Draw, Filtered.
Angell-21	Room C-113, Combination Sink, Bubbler	C	10:33 AM	5	ND	N	First Draw, Filtered.
Angell-22	Room C-113, Combination Sink, Faucet	C	10:34 AM	5	ND	Y	First Draw, Filtered.
Angell-23	Room C-145, Combination Sink, Bubbler	C	10:37 AM	5	ND	N	First Draw, Filtered.
Angell-24	Room C-145, Combination Sink, Faucet	C	10:38 AM	5	ND	Y	First Draw, Filtered.
Angell-25	Room C-147, Combination Sink, Faucet	C	10:41 AM	5	2	Y	First Draw, Filtered.
Angell-26	Hallway, Outside Main Office, Hydration Station, Bottle Fill	BT	10:08 AM	5	ND	N	First Draw, Filtered.
Angell-27	Media Center, Combination Sink, Faucet	C	10:47 AM	5	3	Y	First Draw, Filtered.
Angell-28	Room C-209, Combination Sink, Bubbler	C	10:58 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Angell Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-29	Room C-209, Combination Sink, Faucet	C	10:59 AM	5	ND	Y	First Draw, Filtered.
Angell-30	Room C-212, Combination Sink, Faucet	C	11:02 AM	5	2	Y	First Draw, Filtered.
Angell-31	Room C-217, Combination Sink, Faucet	C	11:20 AM	5	ND	Y	First Draw, Filtered.
Angell-32	Room C-219, Combination Sink, Bubbler	C	11:14 AM	5	ND	N	First Draw, Filtered.
Angell-33	Room C-219, Combination Sink, Faucet	C	11:15 AM	5	ND	Y	First Draw, Filtered.
Angell-34	Room C-221, Combination Sink, Faucet	C	11:12 AM	5	ND	Y	First Draw, Filtered.
Angell-35	Room C-213, Combination Sink, Bubbler	C	11:07 AM	5	ND	N	First Draw, Filtered.
Angell-36	Room C-213, Combination Sink, Faucet	C	11:08 AM	5	1	Y	First Draw, Filtered.
Angell-37	Room C-101, Combination Sink, Faucet	C	10:18 AM	5	ND	Y	First Draw, Filtered.
Angell-38	Teacher's Lounge, Single Sink Faucet	F	11:30 AM	5	ND	Y	First Draw, Filtered.
Angell-39	Main Office, Single Sink Faucet	F	10:14 AM	5	ND	Y	First Draw, Filtered.
Angell-40	Room C-207, Combination Sink, Faucet	C	10:55 AM	5	ND	Y	First Draw, Filtered.
Angell-41	Cafeteria, Hydration Station, Bottle Fill	BT	11:35 AM	5	ND	N	First Draw, Filtered.
Angell-42	Cafeteria, Hydration Station, Water Cooler	BT	11:26 AM	5	ND	N	First Draw, Filtered.
Angell-43	Hallway, Outside Room C-110, Hydration Station, Bottle Fill	BT	10:25 AM	5	ND	N	First Draw, Filtered.
Angell-44	Hallway, Outside Room C-110, Hydration Station, Water Cooler	BT	10:26 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-are-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Angell Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-45	Hallway, Floor 2, Outside Room C-228, Hydration Station, Bottle Fill	BT	10:51 AM	5	ND	N	First Draw, Filtered.
Angell-46	Hallway, Floor 2, Outside Room C-228, Hydration Station, Water Cooler	BT	10:52 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested