



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Bryant Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bryant-01	Hallway, Outside Main Office, Left Single Water Cooler	WC	9:15 AM	5	ND ³	N	First Draw, Filtered.
Bryant-02	Teachers Lounge Sink, Faucet	F	9:30 AM	5	ND	Y	First Draw, Filtered.
Bryant-03	Kitchen, 3-Compartment Sink, Far Left, Faucet	KF	9:20 AM	5	ND	Y	First Draw, Filtered.
Bryant-04	OPEN NUMBER			5			
Bryant-05	Room 200, Bubbler	B	10:50 AM	5	ND	N	First Draw, Filtered.
Bryant-06	Hallway, Outside Room 203, Right Single Water Cooler	WC	10:45 AM	5	ND	N	First Draw, Filtered.
Bryant-07	Between Room 203 & 204, Bubbler	B	10:36 AM	5	ND	N	First Draw, Filtered.
Bryant-08	Room 206, Bubbler	B	10:30 AM	5	ND	N	First Draw, Filtered.
Bryant-09	Between Room 210 & 211, Bubbler	B	10:15 AM	5	ND	N	First Draw, Filtered.
Bryant-10	Room 212, Bubbler	B	10:13 AM	5	ND	N	First Draw, Filtered.
Bryant-11	Room 215, Bubbler	B	10:00 AM	5	ND	N	First Draw, Filtered.
Bryant-12	Hallway, Outside Exit Door 5, By Girls Bathroom, Hydration Station, Water Cooler	BT	9:35 AM	5	ND	N	First Draw, Filtered.
Bryant-13	Hallway, Outside Exit Door 5 by Girls Bathroom, Left Water Cooler	WC	9:35 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Bryant Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bryant-14	Between Room 217 & 218, Bubblers	B	9:50 AM	5	ND	N	First Draw, Filtered.
Bryant-15	Between Room 208 & 209, Bubblers	B	10:20 AM	5	ND	N	First Draw, Filtered.
Bryant-16	Room 216, Bubblers	B	9:55 AM	5	ND	N	First Draw, Filtered.
Bryant-17	Room 207, Bubblers	B	10:25 AM	5	ND	N	First Draw, Filtered.
Bryant-18	Room 205, Bubblers	B	10:34 AM	5	ND	N	First Draw, Filtered.
Bryant-19	Room 214, Bubblers	B	10:02 AM	5	ND	N	First Draw, Filtered.
Bryant-20	Hallway, Outside Room 203, Hydration Station, Water Cooler	BT	10:42 AM	5	ND	N	First Draw, Filtered.
Bryant-21	Room 213, Bubblers	B	10:10 AM	5	ND	N	First Draw, Filtered.
Bryant-22	Hallway, Outside Room 203, Hydration Station, Bottle Fill	BT	10:42 AM	5	ND	N	First Draw, Filtered.
Bryant-23	Room 202, Bubblers	B	10:55 AM	5	ND	N	First Draw, Filtered.
Bryant-24	Room 201, Bubblers	B	10:56 AM	5	ND	N	First Draw, Filtered.
Bryant-25	Hallway, Near Library, Hydration Station, Water Cooler	BT	9:45 AM	5	ND	N	First Draw, Filtered.
Bryant-26	Hallway, Outside Main Office, Hydration Station, Water Cooler	BT	9:16 AM	5	ND	N	First Draw, Filtered.
Bryant-27	Hallway, Outside Main Office, Hydration Station, Bottle Fill	BT	9:16 AM	5	ND	N	First Draw, Filtered.
Bryant-28	Hallway, Outside Exit Door 5 by Girls Bathroom, Hydration Station, Bottle Fill	BT	9:35 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Bryant Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bryant-29	Hallway, Near Library, Hydration Station, Bottle Fill	BT	9:45 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb