



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Burns Park Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Burns-01	Room 110, Combination Sink, Bubblers	C	12:32 PM	5	ND ³	N	First Draw, Filtered.
Burns-02	Hallway, Outside Room 102, Bubblers	B	12:42 PM	5	ND	N	First Draw, Filtered.
Burns-03	Hallway, Outside Kitchen, Hydration Station, Bottle Fill	BT	1:00 PM	5	ND	N	First Draw, Filtered.
Burns-04	Room 213, Combination Sink, Bubblers	C	12:15 PM	5	ND	N	First Draw, Filtered.
Burns-05	Hallway, Outside Media Center, Hydration Station, Water Cooler	BT	12:24 PM	5	ND	N	First Draw, Filtered.
Burns-06	Hallway, Outside Room 302, Water Cooler	WC	12:02 PM	5	ND	N	First Draw, Filtered.
Burns-07	Room 312, Faucet	F	11:57 AM	5	3	Y	First Draw, Filtered.
Burns-08	Hallway, Outside Room 312, Bubblers	B	11:52 AM	5	ND	N	First Draw, Filtered.
Burns-09	Room 103, Combination Sink, Bubblers	B	11:55 AM	5	ND	N	First Draw, Filtered.
Burns-10	Hallway, Outside Kitchen, Hydration Station, Water Cooler	BT	1:01 PM	5	ND	N	First Draw, Filtered.
Burns-11	Room A-6, Combination Sink, Bubblers	C	1:22 PM	5	ND	N	First Draw, Filtered.
Burns-12	Room A-7, Combination Sink, Bubblers	C	1:24 PM	5	ND	N	First Draw, Filtered.
Burns-13	Room A-7, Combination Sink, Faucet	C	1:35 PM	5	2	Y	First Draw, Filtered.
Burns-14	Room A-6, Combination Sink, Faucet	C	1:23 PM	5	7	Y	First Draw, Filtered.
Burns-15	Room A-5, Combination Sink, Bubblers	C	1:19 PM	5	ND	N	First Draw, Filtered.

¹) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
²) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
³) ND = Non Detected at Reported Detection Limit of 1 ug/L
⁴) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Burns Park Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Burns-16	Room A-5, Combination Sink, Faucet	C	1:20 PM	5	ND	Y	First Draw, Filtered.
Burns-17	Room A-3, Combination Sink, Bubblers	C	1:10 PM	5	ND	N	First Draw, Filtered.
Burns-18	Room A-3, Combination Sink, Faucet	C	1:11 PM	5	ND	Y	First Draw, Filtered.
Burns-19	Room A-1, Combination Sink, Bubblers	C	1:05 PM	5	ND	N	First Draw, Filtered.
Burns-20	Room A-1, Combination Sink, Faucet	C	1:06 PM	5	2	Y	First Draw, Filtered.
Burns-21	Room A-4, Combination Sink, Bubblers	C	1:15 PM	5	ND	N	First Draw, Filtered.
Burns-22	Room A-4, Combination Sink, Faucet	C	1:16 PM	5	ND	Y	First Draw, Filtered.
Burns-23	Room A-2, Combination Sink, Bubblers	C	1:13 PM	5	ND	N	First Draw, Filtered.
Burns-24	Room A-2, Combination Sink, Faucet	C	1:14 PM	5	1	Y	First Draw, Filtered.
Burns-25	Kitchen, 3-Compartment, Add On Far Left Faucet	KF	12:59 PM	5	ND	Y	First Draw, Filtered.
Burns-26	Room 103, Combination Sink, Faucet	C	12:56 PM	5	ND	Y	First Draw, Filtered.
Burns-27	Hallway, Outside Room 110, Bubblers	B	12:33 PM	5	ND	N	First Draw, Filtered.
Burns-28	Room 101, Faucet	F	12:52 PM	5	ND	Y	First Draw, Filtered.
Burns-29	Room 102, Faucet	F	12:45 PM	5	ND	Y	First Draw, Filtered.
Burns-30	Room 106, Faucet	F	12:40 PM	5	ND	Y	First Draw, Filtered.
Burns-31	Hallway, Outside Room 101, Hydration Station, Bottle Fill	BT	12:49 PM	5	ND	N	First Draw, Filtered.
Burns-32	Room 110, Combination Sink, Faucet	C	12:38 PM	5	ND	Y	First Draw, Filtered.
Burns-33	Portable, Right Single Water Cooler	WC	1:33 PM	5	ND	N	First Draw, Filtered.

¹) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
²) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
³) ND = Non Detected at Reported Detection Limit of 1 ug/L
⁴) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Burns Park Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Burns-34	Portable, Hydration Station, Water Cooler	BT	1:30 PM	5	ND	N	First Draw, Filtered.
Burns-35	Hallway, Outside Room 101, Hydration Station, Water Cooler	BT	12:50 PM	5	ND	N	First Draw, Filtered.
Burns-36	Room 213, Combination Sink, Faucet	C	12:15 PM	5	ND	Y	First Draw, Filtered.
Burns-37	Room 209, Combination Sink, Bubbler	C	12:17 PM	5	ND	N	First Draw, Filtered.
Burns-38	Room 209, Combination Sink, Faucet	C	12:18 PM	5	ND	Y	First Draw, Filtered.
Burns-39	Office 203, Clinic Faucet	F	12:20 PM	5	ND	N	First Draw, Filtered.
Burns-40	Hallway, Outside Office 203, Bubbler	B	12:22 PM	5	ND	N	First Draw, Filtered.
Burns-41	Media Center, Faucet	F	12:29 PM	5	ND	Y	First Draw, Filtered.
Burns-42	Room 307, Combination Sink, Bubbler	C	12:08 PM	5	ND	N	First Draw, Filtered.
Burns-43	Room 307, Combination Sink, Faucet	C	12:09 PM	5	ND	Y	First Draw, Filtered.
Burns-44	Hallway, Outside Room 301, Hydration Station, Bottle Fill	BT	12:04 PM	5	ND	N	First Draw, Filtered.
Burns-45	Hallway, Outside Room 301, Hydration Station, Water Cooler	BT	12:05 PM	5	ND	N	First Draw, Filtered.
Burns-46	Room 304, Single Sink	F	12:00 PM	5	ND	Y	First Draw, Filtered.
Burns-47	Portable, Hydration Station, Bottle Fill	BT	1:31 PM	5	ND	N	First Draw, Filtered.
Burns-48	Hallway, Outside Media Center, Hydration Station, Bottle Fill	BT	12:25 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Burns Park Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Burns-49	Hallway, Outside Room A-3, Hydration Station, Bottle Fill	BT	1:08 PM	5	ND	N	First Draw, Filtered.
Burns-50	Hallway, Outside Room A-3, Hydration Station, Water Cooler	BT	1:09 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Burns Park Elementary School							
Date of Sampling: 1/18/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Burns-14A	Room A-6, Combination Sink, Faucet	C	9:10 AM	5	1	Y	Repeat First Draw, Filtered. Elevated Lead Attributed to Sediment in Aerator. Aerator Placed on Cleaning Schedule.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb