



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Eberwhite Elementary School							
Date of Sampling: 11/9/2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-01	Room 113, Combination Sink, Bubblers	C	11:39 AM	5	ND ³	N	First Draw, Filtered.
Eberwhite-02	Hallway, Outside Library, Hydration Station, Water Cooler	BT	11:35 AM	5	ND	N	First Draw, Filtered.
Eberwhite-03	Room 111, Combination Sink, Bubblers	C	11:37 AM	5	ND	N	First Draw, Filtered.
Eberwhite-04	Room 127, Combination Sink, Bubblers	C	11:55 AM	5	ND	N	First Draw, Filtered.
Eberwhite-05	OPEN NUMBER						
Eberwhite-06	Room 125, Combination Sink, Bubblers	C	11:52 AM	5	ND	N	First Draw, Filtered.
Eberwhite-07	Library, Single Sink, Faucet	F	11:27 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-08	Hallway, Outside Main Office, Single Water Cooler	WC	11:08 AM	5	ND	N	First Draw, Filtered.
Eberwhite-09	Hallway, Outside Room 122, Left Single Bubblers	BT	12:45 PM	5	ND	N	First Draw, Filtered.
Eberwhite-10	Hallway, Outside Room 122, Right Single Bubblers	B	12:46 PM	5	ND	N	First Draw, Filtered.
Eberwhite-11	Hallway, Outside Main Office, Hydration Station, Bottle Fill	B	11:11 AM	5	ND	N	First Draw, Filtered.
Eberwhite-12	Hallway, Outside Main Office, Hydration Station, Water Cooler	BT	11:12 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Eberwhite Elementary School							
Date of Sampling: 11/9/2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-13	Room 10, Basement, Single Sink, Faucet	F	10:15 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-14	Room 135, Single Sink, Faucet	F	12:29 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-15	Hallway, Outside Library, Hydration Station, Bottle Fill	BT	11:36 AM	5	ND	N	First Draw, Filtered.
Eberwhite-16	Gym, Left Hydration Station, Bottle Fill	BT	11:18 AM	5	ND	N	First Draw, Filtered.
Eberwhite-17	Kitchen, 1-Compartment Sink, Faucet	KF	11:13 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-18	Room 116, Teacher's Lounge, Single Sink, Faucet	F	11:04 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-19	Room 120, Combination Sink, Bubbler	C	12:50 PM	5	ND	N	First Draw, Filtered.
Eberwhite-20	Room 122, Combination Sink, Bubbler	C	12:40 PM	5	ND	N	First Draw, Filtered.
Eberwhite-21	Room 129, Combination Sink, Bubbler	C	11:59 AM	5	ND	N	First Draw, Filtered.
Eberwhite-22	Room 131, Combination Sink, Bubbler	C	12:08 PM	5	ND	N	First Draw, Filtered.
Eberwhite-23	Hallway, Outside Room 126, Hydration Station, Water Cooler	BT	12:04 PM	5	ND	N	First Draw, Filtered.
Eberwhite-24	Hallway, Outside Room 126, Hydration Station, Bottle Fill	BT	12:05 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Eberwhite Elementary School

Date of Sampling: 11/9/2019

Sampler: Alec Staber

Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-25	Room 126, Combination Sink, Bubbler	C	12:32 PM	5	ND	N	First Draw, Filtered.
Eberwhite-26	Room 124, Combination Sink, Bubbler	C	12:36 PM	5	ND	N	First Draw, Filtered.
Eberwhite-27	Room 133, Combination Sink, Bubbler	C	12:17 PM	5	ND	N	First Draw, Filtered.
Eberwhite-28	Room 133, Combination Sink, Faucet	C	12:18 PM	5	1	Y	First Draw, Filtered.
Eberwhite-29	Room 132, Combination Sink, Bubbler	C	12:21 PM	5	ND	N	First Draw, Filtered.
Eberwhite-30	Room 132, Combination Sink, Faucet	C	12:22 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-31	Room 134, Combination Sink Bubbler	C	12:25 PM	5	ND	N	First Draw, Filtered.
Eberwhite-32	Room 134, Combination Sink, Faucet	C	12:26 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-33	Room 114, Combination Sink, Bubbler	C	10:32 AM	5	ND	N	First Draw, Filtered.
Eberwhite-34	Room 102, Combination Sink, Bubbler	C	10:26 AM	5	ND	N	First Draw, Filtered.
Eberwhite-35	Room 112, Combination Sink, Bubbler	C	10:44 AM	5	ND	N	First Draw, Filtered.
Eberwhite-36	Room 110, Combination Sink, Bubbler	C	11:00 AM	5	ND	N	First Draw, Filtered.
Eberwhite-37	Hallway, Outside Room 106, Water Cooler	WC	10:34 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Eberwhite Elementary School							
Date of Sampling: 11/9/2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-38	Hallway, Outside Room 106, Hydration Station, Bottle Fill	BT	10:38 AM	5	ND	N	First Draw, Filtered.
Eberwhite-39	Hallway, Outside Room 106, Hydration Station, Water Cooler	BT	10:39 AM	5	ND	N	First Draw, Filtered.
Eberwhite-40	Room 106, Combination Sink, Bubbler	C	10:50 AM	5	ND	ND	First Draw, Filtered.
Eberwhite-41	Room 108, Combination Sink, Bubbler	C	10:55 AM	5	ND	N	First Draw, Filtered.
Eberwhite-42	Gym, Right Hydration Station, Bottle Fill	BT	11:20 AM	5	ND	N	First Draw, Filtered.
Eberwhite-43	Room 131, Combination Sink, Faucet	C	12:09 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-44	Room 129, Combination Sink, Faucet	C	12:00 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-45	Room 126, Combination Sink, Faucet	C	12:33 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-46	Room 124, Combination Sink, Faucet	C	12:37 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-47	Room 127, Combination Sink, Faucet	C	11:56 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-48	Room 125, Combination Sink, Faucet	C	11:53 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-49	Room 122, Combination Sink, Faucet	C	12:41 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-50	Room 120, Combination Sink, Faucet	C	12:51 PM	5	ND	Y	First Draw, Filtered.
Eberwhite-51	Room 114, Combination Sink, Faucet	C	10:33 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-52	Room 102, Combination Sink, Faucet	C	10:29 AM	5	2	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Eberwhite Elementary School							
Date of Sampling: 11/9/2019							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite-53	Room 112, Combination Sink, Faucet	C	10:45 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-54	Room 106, Combination Sink, Faucet	C	10:51 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-55	Room 110, Combination Sink, Faucet	C	11:01 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-56	Room 108, Combination Sink, Faucet	C	10:56 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-57	Room 113, Combination Sink, Faucet	C	11:40 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-58	Room 111, Combination Sink, Faucet	C	11:32 AM	5	ND	Y	First Draw, Filtered.
Eberwhite-59	Gym, Right Hydration Station, Water Cooler	BT	11:21 AM	5	ND	N	First Draw, Filtered.
Eberwhite-60	Auditorium/Cafeteria Hydration Station, Bottle Fill	BT	10:20 AM	5	ND	N	First Draw, Filtered.
Eberwhite-61	Auditorium/Cafeteria Hydration Station, Water Cooler	BT	10:21 AM	5	ND	N	First Draw, Filtered.
Eberwhite-62	Gym, Left Hydration Station, Bottle Fill	BT	11:19 AM	5	ND	N	First Draw, Filtered.
Eberwhite-63	Exterior of Building, Outside Room 133/131 Exit Door, By Blacktop, Bubbler	B		5			Location Turned off for Winter, to be Sampled at a Later Date.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested