



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Haisley Elementary School							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-01	Hallway, Across from Room 114, Hydration Station, Water Cooler	BT	1:11 PM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Haisley-02	Hallway, Across from Room 200, Hydration Station, Bottle Fill	BT	2:40 PM	5	ND	N	First Draw, Filtered.
Haisley-03	Room 200, Combination Sink, Bubbler	C	2:43 PM	5	ND	N	First Draw, Filtered.
Haisley-04	Room 200, Combination Sink, Faucet	C	2:44 PM	5	ND	Y	First Draw, Filtered.
Haisley-05	Room 112, Combination Sink, Bubbler	C	1:36 PM	5	ND	N	First Draw, Filtered.
Haisley-06	Room 112, Combination Sink, Faucet	C	1:37 PM	5	2	Y	First Draw, Filtered.
Haisley-07	Main Office, Nurse's Sink, Faucet	F	1:01 PM	5	ND	Y	First Draw, Filtered.
Haisley-08	Room 106, Combination Sink, Faucet	C	2:01 PM	5	ND	Y	First Draw, Filtered.
Haisley-09	Room 106, Combination Sink, Bubbler	C	2:02 PM	5	ND	N	First Draw, Filtered.
Haisley-10	Room 102, Combination Sink, Faucet	C	2:20 PM	5	ND	Y	First Draw, Filtered.
Haisley-11	Room 102, Combination Sink, Bubbler	C	2:21 PM	5	ND	N	First Draw, Filtered.
Haisley-12	Main Office Kitchen, Faucet	KF	1:07 PM	5	2	Y	First Draw, Filtered.
Haisley-13	Room 109, Right Combination Sink, Bubbler	C	1:46 PM	5	ND	N	First Draw, Filtered.
Haisley-14	Hallway Across Room 200, Hydration Station, Water Cooler	BT	2:41 PM	5	ND	N	First Draw, Filtered.
Haisley-15	Room 109, Right Combination Sink, Faucet	C	1:47 PM	5	3	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

<b>Haisley Elementary School</b>							
<b>Date of Sampling: 1/18/2020</b>							
<b>Sampler: Carly Doulos</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-16	Room 109, Left Combination Sink, Bubbler	C	1:48 PM	5	ND	N	First Draw, Filtered.
Haisley-17	Room 109, Left Combination Sink, Faucet	C	1:49 PM	5	2	Y	First Draw, Filtered.
Haisley-18	Room 105, Combination Sink, Bubbler	C	2:05 PM	5	ND	N	First Draw, Filtered.
Haisley-19	Room 105, Combination Sink, Faucet	C	2:06 PM	5	1	Y	First Draw, Filtered.
Haisley-20	Room 103, Combination Sink, Bubbler	C	2:15 PM	5	ND	N	First Draw, Filtered.
Haisley-21	Room 103, Combination Sink, Faucet	C	2:16 PM	5	ND	Y	First Draw, Filtered.
Haisley-22	Room 101, Combination Sink, Bubbler	C	2:24 PM	5	ND	N	First Draw, Filtered.
Haisley-23	Room 101, Combination Sink, Faucet	C	2:25 PM	5	ND	Y	First Draw, Filtered.
Haisley-24	Room 100, Combination Sink, Bubbler	C	2:27 PM	5	ND	N	First Draw, Filtered.
Haisley-25	Room 100, Combination Sink, Faucet	C	2:28 PM	5	ND	Y	First Draw, Filtered.
Haisley-26	Room 104, Combination Sink, Bubbler	C	2:11 PM	5	ND	N	First Draw, Filtered.
Haisley-27	Room 104, Combination Sink, Faucet	C	2:12 PM	5	ND	Y	First Draw, Filtered.
Haisley-28	Room 108, Bubbler	B	1:33 PM	5	ND	N	First Draw, Filtered.
Haisley-29	Room 108, Faucet	F	1:54 PM	5	ND	Y	First Draw, Filtered.
Haisley-30	Room 110, Bubbler	B	1:41 PM	5	ND	N	First Draw, Filtered.
Haisley-31	Room 110, Faucet	F	1:42 PM	5	ND	Y	First Draw, Filtered.
Haisley-32	Kitchen, 3-Compartment Add On Single Faucet, Far Right	KF	1:29 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

**Haisley Elementary School**

**Date of Sampling: 1/18/2020**

**Sampler: Carly Doulos**

Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-33	OPEN NUMBER						
Haisley-34	Multi-Purpose Room, Single Water Cooler	WC	1:25 PM	5	ND	N	First Draw, Filtered.
Haisley-35	Multi-Purpose Room, Hydration Station, Bottle Fill	BT	1:22 PM	5	ND	N	First Draw, Filtered.
Haisley-36	Multi-Purpose Room, Hydration Station, Water Cooler	BT	1:23 PM	5	ND	N	First Draw, Filtered.
Haisley-37	Room 113, Single Faucet	F	2:34 PM	5	ND	Y	First Draw, Filtered.
Haisley-38	Room 202, Combination Sink, Bubbler	C	4:08 PM	5	3	N	First Draw, Filtered.
Haisley-39	Room 202, Combination Sink, Faucet	C	4:10 PM	5	1	Y	First Draw, Filtered.
Haisley-40	Room 204, Combination Sink, Bubbler	C	3:33 PM	5	ND	N	First Draw, Filtered.
Haisley-41	Room 204, Combination Sink, Faucet	C	3:34 PM	5	ND	Y	First Draw, Filtered.
Haisley-42	Room 206, Combination Sink, Bubbler	C	3:29 PM	5	ND	N	First Draw, Filtered.
Haisley-43	Room 206, Combination Sink, Faucet	C	3:30 PM	5	2	Y	First Draw, Filtered.
Haisley-44	Room 400, Combination Sink, Bubbler	C	3:25 PM	5	ND	N	First Draw, Filtered.
Haisley-45	Room 400, Combination Sink, Faucet	C	3:27 PM	5	1	Y	First Draw, Filtered.
Haisley-46	Room 402, Combination Sink, Bubbler	C	3:14 PM	5	ND	N	First Draw, Filtered.
Haisley-47	Room 402, Combination Sink, Faucet	C	3:18 PM	5	2	Y	First Draw, Filtered.
Haisley-48	Room 404, Combination Sink, Bubbler	C	3:12 PM	5	ND	N	First Draw, Filtered.
Haisley-49	Room 404, Combination Sink, Faucet	C	3:13 PM	5	2	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

<b>Haisley Elementary School</b>							
<b>Date of Sampling: 1/18/2020</b>							
<b>Sampler: Carly Doulos</b>							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-50	Room 406, Combination Sink, Bubbler	C	3:06 PM	5	ND	N	First Draw, Filtered.
Haisley-51	Room 406, Combination Sink, Faucet	C	3:07 PM	5	1	Y	First Draw, Filtered.
Haisley-52	Room 300, Combination Sink, Bubbler	C	4:04 PM	5	ND	N	First Draw, Filtered.
Haisley-53	Room 300, Combination Sink, Faucet	C	4:05 PM	5	2	Y	First Draw, Filtered.
Haisley-54	Hallway, Outside Room 302, Hydration Station, Water Cooler	BT	3:55 PM	5	ND	N	First Draw, Filtered.
Haisley-55	Room 302, Combination Sink, Bubbler	C	4:00 PM	5	ND	N	First Draw, Filtered.
Haisley-56	Room 302, Combination Sink, Faucet	C	4:02 PM	5	ND	Y	First Draw, Filtered.
Haisley-57	Room 304, Combination Sink, Bubbler	C	3:49 PM	5	ND	N	First Draw, Filtered.
Haisley-58	Room 306, Combination Sink, Bubbler	C	3:41 PM	5	ND	N	First Draw, Filtered.
Haisley-59	Room 306, Combination Sink, Faucet	C	3:42 PM	5	ND	Y	First Draw, Filtered.
Haisley-60	Room 307, Combination Sink, Bubbler	C	3:38 PM	5	ND	N	First Draw, Filtered.
Haisley-61	Room 307, Combination Sink, Faucet	C	3:40 PM	5	2	Y	First Draw, Filtered.
Haisley-62	Room 305, Combination Sink, Bubbler	C	3:46 PM	5	ND	N	First Draw, Filtered.
Haisley-63	Room 305, Combination Sink, Faucet	C	4:47 PM	5	ND	Y	First Draw, Filtered.
Haisley-64	Hallway, Outside Room 302, Hydration Station, Bottle Fill	BT	3:57 PM	5	ND	N	First Draw, Filtered.
Haisley-65	Hallway, Outside Room 402, Hydration Station, Water Cooler	BT	3:20 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Haisley Elementary School							
Date of Sampling: 1/18/2020							
Sampler: Carly Doulos							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley-66	Hallway, Outside Room 402, Hydration Station, Bottle Fill	BT	3:21 PM	5	ND	N	First Draw, Filtered.
Haisley-67	Hallway Across Room 114, Hydration Station, Bottle Fill	BT	1:13 PM	5	ND	N	First Draw, Filtered.
Haisley-68	Hallway, Outside Room 108, Hydration Station, Water Cooler	BT	1:56 PM	5	ND	N	First Draw, Filtered.
Haisley-69	Hallway, Outside Room 108, Hydration Station, Bottle Fill	BT	1:57 PM	5	ND	N	First Draw, Filtered.
Haisley-70	Room 304, Combination Sink, Faucet	C	3:51 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb