



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-40	Room Between Room 2201 and Room 2200, 2-Compartment Sink, "Green House", Kitchen Faucet	KF	12:05 PM	5	ND	Y	First Draw, Filtered.
Huron-41	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Single Water Cooler	WC	12:10 PM	5	ND	N	First Draw, Filtered.
Huron-42	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Hydration Station, Water Cooler	BT	12:10 PM	5	ND	N	First Draw, Filtered.
Huron-43	Dome Gym, South Single Bubbler	B	12:22 PM	5	ND	N	First Draw, Filtered.
Huron-44	Dome Gym, North Single Bubbler			5			Location Not Currently Functional
Huron-45	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Ice Machine			5			Exterior Locations to be Sampled at a Later Date
Huron-49	Upper Gym, Above Pool, Between Restrooms, Right Water Cooler	WC	12:30 PM	5	ND	N	First Draw, Filtered.
Huron-50	Upper Gym, Above Pool, Between Restrooms, Left Water Cooler	WC	12:30 PM	5	ND	N	First Draw, Filtered.
Huron-51	Hallway, Southeast Wing, Floor 2, Across from Room 6212, Single Water Cooler	WC	11:50 AM	5	ND	N	First Draw, Filtered.
Huron-52	Room 6216, 2-Compartment Sink, Faucet	F	11:52 AM	5	ND	Y	First Draw, Filtered.
Huron-53	Room 6218, 2-Compartment Sink, Faucet	F	11:07 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-54	Hallway, Southeast Wing, Floor 2, Outside Room 6203, Hydration Station, Water Cooler	BT	11:42 AM	5	ND	N	First Draw, Filtered.
Huron-55	Life Skills Room 6219, South Wall, 2-Compartment Kitchen Sink	KF	11:26 AM	5	ND	Y	First Draw, Filtered.
Huron-56	Life Skills Room 6219, East Wall, Right, 2-Compartment Kitchen Sink	KF	11:25 AM	5	ND	Y	First Draw, Filtered.
Huron-57	Life Skills Room 6219, East Wall, Middle, 2-Compartment Kitchen Sink	KF	11:24 AM	5	ND	Y	First Draw, Filtered.
Huron-58	Life Skills Room 6219, East Wall, Left, 2-Compartment Kitchen Sink	KF	11:23 AM	5	ND	Y	First Draw, Filtered.
Huron-59	OPEN NUMBER			5			
Huron-60	Life Skills Room 6219, West Wall, 2-Compartment Kitchen Sink	KF	11:12 AM	5	ND	Y	First Draw, Filtered.
Huron-61	Life Skills Room 6219, West Wall, Middle, 2-Compartment Kitchen Sink	KF	11:13 AM	5	ND	Y	First Draw, Filtered.
Huron-62	Life Skills Room 6219, West Wall, Right, 2-Compartment Kitchen Sink	KF	11:14 AM	5	ND	Y	First Draw, Filtered.
Huron-63	Life Skills Room 6219, Ice Machine	I	11:15 AM	5	ND	N	First Draw, Filtered.
Huron-64	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Single Water Cooler	WC	11:00 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-65	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Hydration Station, Water Cooler	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Huron-66	Hallway, Floor 3, Outside Room 4311, Hydration Station, Bottle Fill	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Huron-67	Hallway, Floor 3, Outside Room 4311, Hydration Station, Water Cooler	BT	12:57 PM	5	ND	N	First Draw, Filtered.
Huron-68	Hallway, Floor 3, Outside Room 4313, Hydration Station, Water Cooler	BT	12:50 PM	5	ND	N	First Draw, Filtered.
Huron-69	Hallway, Floor 3, Outside Room 4300, Single Water Cooler	WC	12:42 PM	5	ND	N	First Draw, Filtered.
Huron-70	Hallway, Floor 3, Outside Room 4321, Hydration Station, Water Cooler	BT	12:45 PM	5	ND	N	First Draw, Filtered.
Huron-74	Cafeteria, East , Outside Service Area, Hydration Station, Bottle Fill	BT	9:15 AM	5	ND	N	First Draw, Filtered.
Huron-75	Cafeteria, West, Outside Kitchen, Hydration Station, Bottle Fill	BT	9:20 AM	5	ND	N	First Draw, Filtered.
Huron-78	Hallway, Northwest Wing, Floor 2, Across from Room 2201, Hydration Station, Bottle Fill	BT	12:10 PM	5	ND	N	First Draw, Filtered.
Huron-79	Hallway, Southeast Wing, Floor 2, Outside Room 6203, Hydration Station, Bottle Fill	BT	11:42 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-80	Hallway, Floor 3, Outside Room 4313, Hydration Station, Bottle Fill	BT	12:50 PM	5	ND	N	First Draw, Filtered.
Huron-81	Hallway, Floor 3, Outside Room 4321, Hydration Station, Bottle Fill	BT	12:45 PM	5	ND	N	First Draw, Filtered.
Huron-82	OPEN NUMBER			5			
Huron-83	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Right Hydration Station, Water Cooler	BT	10:10 AM	5	ND	N	First Draw, Filtered.
Huron-84	Hallway, Southeast Wing, Floor 1, Outside of Media Center, Right Hydration Station, Bottle Fill	BT	10:10 AM	5	ND	N	First Draw, Filtered.
Huron-85	Kitchen, Northwest Corner, Ice Machine	I	9:25 AM	5	ND	N	First Draw, Filtered.
Huron-86	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Bottle Fill			5			Exterior Locations to be Sampled at a Later Date
Huron-87	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Water Cooler			5			Exterior Locations to be Sampled at a Later Date
Huron-88	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Single Water Cooler			5			Exterior Locations to be Sampled at a Later Date

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-89	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Bottle Fill			5			Exterior Locations to be Sampled at a Later Date
Huron-90	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Water Cooler			5			Exterior Locations to be Sampled at a Later Date
Huron-91	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Single Water Cooler			5			Exterior Locations to be Sampled at a Later Date
Huron-92	Outbuilding, Football Field, Locker Room Clinic, Single Sink			5			Exterior Locations to be Sampled at a Later Date
Huron-93	Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Bubbler Outlet			5			Exterior Locations to be Sampled at a Later Date
Huron-94	Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Glass Filler Outlet			5			Exterior Locations to be Sampled at a Later Date
Huron-95	Outbuilding, Football Field, Concessions, 3-Compartment Add On, Single Cold Water Faucet, Far Right Faucet			5			Exterior Locations to be Sampled at a Later Date
Huron-96	Outbuilding, Soccer Field, Double Bubbler (Side Bubbler) on Exterior of Building			5			Exterior Locations to be Sampled at a Later Date
Huron-97	Outbuilding, Soccer Field, Double Bubbler (Top Bubbler) on Exterior of Building			5			Exterior Locations to be Sampled at a Later Date

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/10/2020							
Sampler: Kellie Das & Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-98	Outbuilding, Soccer Field, Double Bubbler (Glass Filler) on Exterior of Building			5			Exterior Locations to be Sampled at a Later Date
Huron-99	Outbuilding, West of Soccer Field, Double Bubbler (Side Bubbler), Outside Small Shed			5			Exterior Locations to be Sampled at a Later Date
Huron-100	Outbuilding, West of Soccer Field, Double Bubbler (Top Bubbler), Outside Small Shed			5			Exterior Locations to be Sampled at a Later Date
Huron-101	Outbuilding, West of Soccer Field, Double Bubbler (Glass Filler), Outside Small Shed			5			Exterior Locations to be Sampled at a Later Date
Huron-102	Hallway, Southeast Wing, Floor 2, Across from Room 5200, Hydration Station, Bottle Fill	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Huron-103	Hallway, Southeast Wing, Floor 1, Across from Room 7152, Hydration Station, Bottle Fill	BT	10:15 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/14/2020							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-01	Hallway, Southeast Wing, Floor 1, Across from Room 6156, Single Water Cooler	WC	8:39 AM	5	ND	N	First Draw, Filtered.
Huron-02	Hallway, Southeast Wing, Floor 1, Across from Main Office, Single Water Cooler	WC	8:34 AM	5	ND	N	First Draw, Filtered.
Huron-03	Hallway, Southeast Wing, Floor 1, Across from Main Office, Hydration Station, Water Cooler	BT	8:34 AM	5	ND	N	First Draw, Filtered.
Huron-04	Hallway, Southeast Wing, Floor 1, Across from Main Office, Hydration Station, Bottle Fill	BT	8:35 AM	5	ND	N	First Draw, Filtered.
Huron-05	Fitness Center, Northwest Hydration Station, Bottle Fill	BT	9:37 AM	5	ND	N	First Draw, Filtered.
Huron-08	Hallway, Northwest Wing, Outside of Cafeteria, Left Hydration Station, Water Cooler	BT	9:20 AM	5	ND	N	First Draw, Filtered.
Huron-09	Hallway, Northwest Wing, Outside of Cafeteria, Left Hydration Station, Bottle Fill	BT	9:20 AM	5	ND	N	First Draw, Filtered.
Huron-12	Hallway, Northwest Wing, Floor 1, Outside Room 1110, Hydration Station, Water Cooler	BT	9:26 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/14/2020							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-13	Hallway, Floor 1, Southeast Wing, Outside Room 7109, Left Single Water Cooler	WC	9:03 AM	5	ND	N	First Draw, Filtered.
Huron-15	Fitness Center, Southeast Water Cooler	WC	9:34 AM	5	ND	N	First Draw, Filtered.
Huron-16	Fitness Center, Northwest Hydration Station, Water Cooler	BT	9:37 AM	5	ND	N	First Draw, Filtered.
Huron-20	Hallway, Northwest Wing, Outside of Cafeteria, Right Hydration Station, Water Cooler	BT	9:17 AM	5	ND	N	First Draw, Filtered.
Huron-22	Hallway, Northwest Wing, Outside of Cafeteria, Right Hydration Station, Bottle Fill	BT	9:17 AM	5	ND	N	First Draw, Filtered.
Huron-34	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Hydration Station, Water Cooler	BT	8:47 AM	5	ND	N	First Draw, Filtered.
Huron-38	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Hydration Station, Water Cooler	BT	9:52 AM	5	ND	N	First Draw, Filtered.
Huron-39	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Single Water Cooler	WC	9:50 AM	5	ND	N	First Draw, Filtered.
Huron-44	Dome Gym, North Single Bubbler	B	10:00 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School							
Date of Sampling: 3/14/2020							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-46	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Hydration Station, Water Cooler	BT	10:10 AM	5	ND	N	First Draw, Filtered.
Huron-47	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Hydration Station, Bottle Fill	BT	10:10 AM	5	ND	N	First Draw, Filtered.
Huron-48	Hallway, Northwest Wing, Floor 2, Outside Upper Gym, Single Water Cooler	WC	10:13 AM	5	ND	N	First Draw, Filtered.
Huron-71	Hallway, Floor 1, Southeast Wing, Outside Room 7109, Hydration Station, Water Cooler	BT	9:04 AM	5	ND	N	First Draw, Filtered.
Huron-72	Hallway, Floor 1, Southeast Wing, Outside Room 7109, Hydration Station, Bottle Fill	BT	9:04 AM	5	ND	N	First Draw, Filtered.
Huron-73	Hallway, Northwest Wing, Floor 1, Outside Room 1110, Hydration Station, Bottle Fill	BT	9:27 AM	5	ND	N	First Draw, Filtered.
Huron-76	Hallway, Southeast Wing, Floor 1, Across from Room 7150, Hydration Station, Bottle Fill	BT	8:48 AM	5	ND	N	First Draw, Filtered.
Huron-77	Hallway, Northwest Wing, Floor 2, Across from Room 3201, Hydration Station, Bottle Fill	BT	9:52 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School-Exterior Locations							
Date of Sampling: 3/19/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-45	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Ice Machine	I	9:08 AM	5	ND ³	N	First Draw, Filtered. Location Previously Winterized.
Huron-86	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Bottle Fill	BT	8:15 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-87	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Water Cooler	BT	7:55 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-88	Outbuilding, Football Field, NW Locker Room, Closest to Stands, Single Water Cooler	WC	8:10 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-89	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Bottle Fill	BT	8:45 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-90	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Water Cooler	BT	8:36 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-91	Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Single Water Cooler	WC	8:26 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Huron High School-Exterior Locations							
Date of Sampling: 3/19/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Huron-92	Outbuilding, Football Field, Locker Room Clinic, Single Sink	F	7:45 AM	5	1	Y	First Draw, Filtered. Location Previously Winterized.
Huron-93	Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Bubbler Outlet	BT	9:25 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-94	Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Glass Filler Outlet	BT	9:25 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-95	Outbuilding, Football Field, Concessions, 3-Compartment Add On, Single Cold Water Faucet, Far Right Faucet	KF	7:30 AM	5	ND	Y	First Draw, Filtered. Location Previously Winterized.
Huron-96	Outbuilding, Soccer Field, Double Bubbler (Side Bubbler) on Exterior of Building	B	9:55 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-97	Outbuilding, Soccer Field, Double Bubbler (Top Bubbler) on Exterior of Building			5			Location Winterized, Unable to Sample.
Huron-98	Outbuilding, Soccer Field, Double Bubbler (Glass Filler) on Exterior of Building	BT	10:10 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-99	Bubbler (Side Bubbler), Outside Small Shed	B	10:30 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-100	Outbuilding, West of Soccer Field, Double Bubbler (Top Bubbler), Outside Small Shed	BT	10:30 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.
Huron-101	Outbuilding, West of Soccer Field, Double Bubbler (Glass Filler), Outside Small Shed	BT	10:30 AM	5	ND	N	First Draw, Filtered. Location Previously Winterized.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Huron High School Sampling Results Table

HURON HIGH SCHOOL-EXTERIOR LOCATIONS				
Location	Parameter	Result	MCL/AL	Method Reference
Huron-45: Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Ice Machine	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-86: Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-87: Outbuilding, Football Field, NW Locker Room, Closest to Stands, Hydration Station, Water Cooler	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-88: Outbuilding, Football Field, NW Locker Room, Closest to Stands, Single Water Cooler	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-89: Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Bottle Fill	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-90: Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Hydration Station, Water Cooler	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-91: Outbuilding, Football Field, SE Locker Room, Closest to Baseball Field, Single Water Cooler	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-92: Outbuilding, Football Field, Locker Room Clinic, Single Sink	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-93: Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Bubbler Outlet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-94: Outbuilding, Baseball Field Bathrooms, Bubbler/Glass Fill, Glass Filler Outlet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035

Sampling Date: March 19, 2020

Sampler: Alex Reiber

Huron High School Sampling Results Table

HURON HIGH SCHOOL-EXTERIOR LOCATIONS				
Location	Parameter	Result	MCL/AL	Method Reference
Huron-95: Outbuilding, Football Field, Concessions, 3-Compartment Add On, Single Cold Water Faucet, Far Right Faucet	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-96: Outbuilding, Soccer Field, Double Bubbler (Side Bubbler) on Exterior of Building	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-97: Outbuilding, Soccer Field, Double Bubbler (Top Bubbler) on Exterior of Building	<i>E. coli</i>	Not Functional at Time of Sampling	Zero	ATP D05-0035
	Coliform	Not Functional at Time of Sampling	Zero	ATP D05-0035
Huron-98: Outbuilding, Soccer Field, Double Bubbler (Glass Filler) on Exterior of Building	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-99: Outbuilding, West of Soccer Field, Double Bubbler (Side Bubbler), Outside Small Shed	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-100: Outbuilding, West of Soccer Field, Double Bubbler (Top Bubbler), Outside Small Shed	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035
Huron-101: Outbuilding, West of Soccer Field, Double Bubbler (Glass Filler), Outside Small Shed	<i>E. coli</i>	Negative	Zero	ATP D05-0035
	Coliform	Negative	Zero	ATP D05-0035