



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

King Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
King-01	Hallway, Outside Main Office, Right Single Water Cooler	WC	8:55 AM	5	ND ³	N	First Draw, Filtered.
King-02	Psychology and Social Work Room, East Faucet	F	10:41 AM	5	1	Y	First Draw, Filtered.
King-03	Hallway, Outside Room 113, Hydration Station, Water Cooler	BT	9:40 AM	5	ND	N	First Draw, Filtered.
King-04	Hallway, Between Music Room and Gym, Hydration Station, Water Cooler	BT	10:37 AM	5	ND	N	First Draw, Filtered.
King-05	Room 106, Combination Sink, Bubbler	C	10:21 AM	5	ND	N	First Draw, Filtered.
King-06	Room 107, Combination Sink, Bubbler	C	10:05 AM	5	ND	N	First Draw, Filtered.
King-07	Room 108, Combination Sink, Faucet	C	10:00 AM	5	ND	Y	First Draw, Filtered.
King-08	Room 110, Combination Sink, Bubbler	C	9:53 AM	5	ND	N	First Draw, Filtered.
King-09	Room 118, Combination Sink, Faucet	C	9:07 AM	5	ND	Y	First Draw, Filtered.
King-10	Clinic in Main Office, Combination Sink, Faucet	C	8:57 AM	5	2	Y	First Draw, Filtered.
King-11	Room 109, Combination Sink, Bubbler	C	9:56 AM	5	ND	N	First Draw, Filtered.
King-12	Room 104, Combination Sink, Faucet	C	10:13 AM	5	ND	Y	First Draw, Filtered.
King-13	Hallway, Outside Room 113, Hydration Station, Bottle Fill	BT	9:41 AM	5	ND	N	First Draw, Filtered.
King-14	Main Office, Workroom, Faucet	F	8:57 AM	5	5	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

King Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
King-15	Hallway Across from Main Office, Hydration Station, Water Cooler	BT	8:53 AM	5	ND	N	First Draw, Filtered.
King-16	Hallway Across from Main Office, Hydration Station, Bottle Fill	BT	8:54 AM	5	ND	N	First Draw, Filtered.
King-17	King Care Room, Faucet	F	10:43 AM	5	2	Y	First Draw, Filtered.
King-18	Hallway, Between Music Room and Gym, Hydration Station, Bottle Fill	BT	10:38 AM	5	ND	N	First Draw, Filtered.
King-19	Kitchen, 3-Compartment Sink, Add On Faucet, Far Left	KF	10:35 AM	5	ND	Y	First Draw, Filtered.
King-20	OPEN NUMBER						
King-21	Room KI-K1, Combination Sink, Bubbler	C	10:28 AM	5	ND	N	First Draw, Filtered.
King-22	Room KI-K1, Combination Sink, Faucet	C	10:29 AM	5	ND	Y	First Draw, Filtered.
King-23	Room KI-K2, Combination Sink, Bubbler	C	10:25 AM	5	ND	N	First Draw, Filtered.
King-24	Room KI-K2, Combination Sink, Faucet	C	10:26 AM	5	ND	Y	First Draw, Filtered.
King-25	Room 106, Combination Sink, Faucet	C	10:22 AM	5	ND	Y	First Draw, Filtered.
King-26	Room 107, Combination Sink, Faucet	C	10:06 AM	5	ND	Y	First Draw, Filtered.
King-27	Room 108, Combination Sink, Bubbler	C	10:01 AM	5	ND	N	First Draw, Filtered.
King-28	Room 109, Combination Sink, Faucet	C	9:59 AM	5	ND	Y	First Draw, Filtered.
King-29	Room 110, Combination Sink, Faucet	C	9:54 AM	5	ND	Y	First Draw, Filtered.
King-30	Room 111, Combination Sink, Bubbler	C	9:49 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

King Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
King-31	Room 111, Combination Sink, Faucet	C	9:50 AM	5	ND	Y	First Draw, Filtered.
King-32	Room 112, Combination Sink, Bubbler	C	9:46 AM	5	ND	N	First Draw, Filtered.
King-33	Room 112, Combination Sink, Faucet	C	9:47 AM	5	ND	Y	First Draw, Filtered.
King-34	Room 113, Combination Sink, Bubbler	C	9:43 AM	5	ND	N	First Draw, Filtered.
King-35	Room 113, Combination Sink, Faucet	C	9:44 AM	5	5	Y	First Draw, Filtered.
King-36	Room 114, Combination Sink, Bubbler	C	9:29 AM	5	ND	N	First Draw, Filtered.
King-37	Room 114, Combination Sink, Faucet	C	9:28 AM	5	2	Y	First Draw, Filtered.
King-38	Room 115, Combination Sink, Bubbler	C	9:24 AM	5	ND	N	First Draw, Filtered.
King-39	Room 115, Combination Sink, Faucet	C	9:25 AM	5	ND	Y	First Draw, Filtered.
King-40	Room 116, Combination Sink, Bubbler	C	9:20 AM	5	ND	N	First Draw, Filtered.
King-41	Room 116, Combination Sink, Faucet	C	9:21 AM	5	ND	Y	First Draw, Filtered.
King-42	Room 117, Combination Sink, Bubbler	C	9:17 AM	5	ND	N	First Draw, Filtered.
King-43	Room 117, Combination Sink, Faucet	C	9:18 AM	5	1	N	First Draw, Filtered.
King-44	Room 118, Combination Sink, Bubbler	C	9:10 AM	5	ND	N	First Draw, Filtered.
King-45	Room 101, Combination Sink, Bubbler	C	9:06 AM	5	ND	N	First Draw, Filtered.
King-46	Room 101, Combination Sink, Faucet	C	9:07 AM	5	ND	Y	First Draw, Filtered.
King-47	Room 102, Combination Sink, Bubbler	C	9:14 AM	5	ND	N	First Draw, Filtered.
King-48	Room 102, Combination Sink, Faucet	C	9:15 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

King Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
King-49	Room 103, Combination Sink, Bubbler	C	10:17 AM	5	ND	N	First Draw, Filtered.
King-50	Room 103, Combination Sink, Faucet	C	10:18 AM	5	ND	Y	First Draw, Filtered.
King-51	Room 104, Combination Sink, Bubbler	C	10:14 AM	5	ND	N	First Draw, Filtered.
King-52	Room 105, Combination Sink, Bubbler	C	10:09 AM	5	ND	N	First Draw, Filtered.
King-53	Room 105, Combination Sink, Faucet	C	10:10 AM	5	1	Y	First Draw, Filtered.
King-54	Portable, Hydration Station, Water Cooler	BT	10:49 AM	5	ND	N	First Draw, Filtered.
King-55	Portable, Single Water Cooler	WC	10:48 AM	5	ND	N	First Draw, Filtered.
King-56	Learning Center, Single Sink Faucet			5			Location Not Functional
King-57	Portable, Hydration Station, Bottle Fill	BT	10:50 AM	5	ND	N	First Draw, Filtered.
King-58	Hallway, Outside Room C-107, Hydration Station, Water Cooler	BT	10:03 AM	5	ND	N	First Draw, Filtered.
King-59	Hallway, Outside Room C-107, Hydration Station, Bottle Fill	BT	10:04 AM	5	ND	N	First Draw, Filtered.
King-60	Hallway, Outside Room C-101, Hydration Station, Water Cooler	BT	9:03 AM	5	ND	N	First Draw, Filtered.
King-61	Hallway, Outside Room C-101, Hydration Station, Bottle Fill	BT	9:04 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

King Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
King-56	Learning Center, Single Sink Faucet	F	2:18 PM	5	1	Y	First Draw, Filtered. Location Previously Not Functional.

1) Type: B = Bubble, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested