



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Lakewood Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood -01	Teacher's Lounge Across from Main Office, Faucet	KF	10:00 AM	5	ND <sup>3</sup>	Y	First Draw, Filtered.
Lakewood -02	Hallway, Outside Main Office, Hydration Station, Water Cooler	BT	10:05 AM	5	ND	N	First Draw, Filtered.
Lakewood -03	Room 103, Single Sink Faucet	F					Location Not Currently Functional
Lakewood -04	Room 109, Combination Sink, Faucet	C	10:50 AM	5	ND	Y	First Draw, Filtered.
Lakewood -05	Room 109, Combination Sink, Bubbler	C	10:50 AM	5	ND	N	First Draw, Filtered.
Lakewood -06	Hallway, Outside of Gym, Hydration Station, Water Cooler	BT	11:15 AM	5	ND	N	First Draw, Filtered.
Lakewood -07	Room 108, Combination Sink, Faucet	C	11:05 AM	5	ND	Y	First Draw, Filtered.
Lakewood -08	Room 108, Combination Sink, Bubbler	C	11:05 AM	5	ND	N	First Draw, Filtered.
Lakewood -09	Hallway, Outside Main Office, Hydration Station, Bottle Fill	BT	10:05 AM	5	ND	Y	First Draw, Filtered.
Lakewood -10	Hallway, Outside of Kitchen, Hydration Station, Water Cooler	BT	8:20 AM	5	ND	N	First Draw, Filtered.
Lakewood -11	Kitchen, 3-Compartment, Single Add On Faucet, Far Right Faucet	KF	8:30 AM	5	ND	Y	First Draw, Filtered.
Lakewood -12	Room A-5, Combination Sink, Bubbler	C	8:50 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Lakewood Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood -13	Room A-5, Combination Sink, Faucet	C	8:50 AM	5	ND	N	First Draw, Filtered.
Lakewood -14	Room A-6, Combination Sink, Bubblers	C	8:45 AM	5	ND	N	First Draw, Filtered.
Lakewood -15	Room A-6, Combination Sink, Faucet	C	8:45 AM	5	ND	Y	First Draw, Filtered.
Lakewood -16	Room A-4, Combination Sink, Bubblers	C	9:00 AM	5	ND	N	First Draw, Filtered.
Lakewood -17	Room A-4, Combination Sink, Faucet	C	9:00 AM	5	ND	N	First Draw, Filtered.
Lakewood -18	Room A-3, Combination Sink, Bubblers	C	9:35 AM	5	ND	N	First Draw, Filtered.
Lakewood -19	Room A-3, Combination Sink, Faucet	C	9:35 AM	5	ND	N	First Draw, Filtered.
Lakewood -20	Room A-2, Combination Sink, Bubblers	C	9:30 AM	5	ND	N	First Draw, Filtered.
Lakewood -21	Room A-2, Combination Sink, Faucet	C	9:30 AM	5	ND	Y	First Draw, Filtered.
Lakewood -22	Room A-1, Combination Sink, Bubblers	C	9:10 AM	5	2	N	First Draw, Filtered.
Lakewood -23	Room A-1, Combination Sink, Faucet	C	9:10 AM	5	ND	N	First Draw, Filtered.
Lakewood -24	A-Wing Common Room, Outside Room A-6, Single Sink Faucet	F	8:37 AM	5	ND	Y	First Draw, Filtered.
Lakewood -25	A-Wing Common Room, Outside Room A-1, Single Sink Faucet	F	9:15 AM	5	ND	Y	First Draw, Filtered.
Lakewood -26	Hallway, Outside of Kitchen, Hydration Station, Bottle Fill	BT	8:20 AM	5	ND	Y	First Draw, Filtered.
Lakewood -27	Cafeteria, Right Combination Bubblers/Bottle Fill, Bubblers Outlet	BT	9:50 AM	5	ND	N	First Draw, Filtered.
Lakewood -28	Clinic, Combination Sink, Bubblers	C	10:10 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Lakewood Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood -29	Clinic, Combination Sink, Faucet	C	10:10 AM	5	ND	Y	First Draw, Filtered.
Lakewood -30	D-Wing Common Room, Outside Room D-6, Single Sink Faucet	F	12:20 PM	5	ND	Y	First Draw, Filtered.
Lakewood -31	Room 106, Combination Sink, Bubbler	C	10:40 AM	5	ND	N	First Draw, Filtered.
Lakewood -32	Room 106, Combination Sink, Faucet	C	10:40 AM	5	ND	Y	First Draw, Filtered.
Lakewood -33	Room 107, Combination Sink, Bubbler	C	11:00 AM	5	ND	N	First Draw, Filtered.
Lakewood -34	Room 107, Combination Sink, Faucet	C	11:00 AM	5	ND	N	First Draw, Filtered.
Lakewood -35	Hallway, Outside of Gym, Single Water Cooler	WC	11:10 AM	5	ND	N	First Draw, Filtered.
Lakewood -36	Room D-4, Combination Sink, Bubbler	C	12:00 PM	5	ND	N	First Draw, Filtered.
Lakewood -37	Room D-4, Combination Sink, Faucet	C	12:00 PM	5	ND	Y	First Draw, Filtered.
Lakewood -38	Room D-5, Combination Sink, Bubbler	C	12:05 PM	5	ND	N	First Draw, Filtered.
Lakewood -39	Room D-5, Combination Sink, Faucet	C	12:05 PM	5	ND	Y	First Draw, Filtered.
Lakewood -40	Room D-6, Combination Sink, Bubbler	C	12:15 PM	5	ND	N	First Draw, Filtered.
Lakewood -41	Room D-6, Combination Sink, Faucet	C	12:15 PM	5	ND	Y	First Draw, Filtered.
Lakewood -42	Room D-1, Combination Sink, Bubbler	C	11:35 AM	5	ND	N	First Draw, Filtered.
Lakewood -43	Room D-1, Combination Sink, Faucet	C	11:35 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminante>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Lakewood Elementary School							
Date of Sampling: 12/21/2019							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood -44	Room D-2, Combination Sink, Bubblers	C	11:40 AM	5	ND	N	First Draw, Filtered.
Lakewood -45	Room D-2, Combination Sink, Faucet	C	11:40 AM	5	ND	Y	First Draw, Filtered.
Lakewood -46	Room D-3, Combination Sink, Bubblers	C	11:50 AM	5	ND	N	First Draw, Filtered.
Lakewood -47	Room D-3, Combination Sink, Faucet	C	11:50 AM	5	ND	Y	First Draw, Filtered.
Lakewood -48	D-Wing Common Room, Outside Room D-1, Single Sink Faucet	F	11:25 AM	5	ND	Y	First Draw, Filtered.
Lakewood -49	Cafeteria, Right Combination Bubblers/Bottle Fill, Glass Filler Outlet	BT	9:50 AM	5	ND	N	First Draw, Filtered.
Lakewood -50	Cafeteria, Left Combination Bubblers/Bottle Fill, Bubblers Outlet	BT	9:45 AM	5	ND	N	First Draw, Filtered.
Lakewood -51	Cafeteria, Left Combination Bubblers/Bottle Fill, Glass Filler Outlet	BT	9:45 AM	5	ND	N	First Draw, Filtered.
Lakewood -52	Hallway, Outside of Gym, Hydration Station, Bottle Fill	BT	11:15 AM	5	ND	Y	First Draw, Filtered.
Lakewood -53	A-Wing Common Room, Outside Room A-3, Hydration Station, Water Cooler	BT	9:20 AM	5	ND	N	First Draw, Filtered.
Lakewood -54	A-Wing Common Room, Outside Room A-3, Hydration Station, Bottle Fill	BT	9:20 AM	5	ND	Y	First Draw, Filtered.
Lakewood -55	D-Wing Common Room, Outside Room D-6, Hydration Station, Water Cooler	BT	12:25 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/you-r-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030

Lakewood Elementary School							
Date of Sampling: 1/3/2020							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood-03	Room 103, Single Sink, Faucet	F	12:50 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
4) NT = Not Tested

Action Level >5ppb