



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-01	Room 310, Combination Sink, Bubbler	C	1:17 PM	5	ND ³	N	First Draw, Filtered.
Lawton-02	Room 312, Combination Sink, Faucet	C	1:54 PM	5	ND	Y	First Draw, Filtered.
Lawton-03	Room 316, Combination Sink, Bubbler	C	2:01 PM	5	ND	N	First Draw, Filtered.
Lawton-04	Room 314, Combination Sink, Faucet	C	1:58 PM	5	ND	Y	First Draw, Filtered.
Lawton-05	Room 210, Combination Sink, Bubbler	C	1:09 PM	5	ND	N	First Draw, Filtered.
Lawton-06	Cafeteria/Auditorium, Right Water Cooler	WC	12:54 PM	5	ND	N	First Draw, Filtered.
Lawton-07	Kitchen, 3-Compartment Sink, Add On Faucet, Far Right	KF	12:58 PM	5	ND	Y	First Draw, Filtered.
Lawton-08	Gym, Single Bubbler	B	12:52 PM	5	ND	N	First Draw, Filtered.
Lawton-09	Room 218, Combination Sink, Faucet	C	12:37 PM	5	1	Y	First Draw, Filtered.
Lawton-10	Room 203, Combination Sink, Bubbler	C	12:44 PM	5	ND	N	First Draw, Filtered.
Lawton-11	Room 201, Combination Sink, Faucet	C	12:37 PM	5	ND	Y	First Draw, Filtered.
Lawton-12	Room 210, Combination Sink, Faucet	C	1:10 PM	5	1	Y	First Draw, Filtered.
Lawton-13	Room 312, Combination Sink, Bubbler	C	1:55 PM	5	ND	N	First Draw, Filtered.
Lawton-14	Room 314, Combination Sink, Bubbler	C	1:59 PM	5	ND	N	First Draw, Filtered.
Lawton-15	Room 313, Kitchen Faucet	KF	1:56 PM	5	9	Y	First Draw, Filtered.
Lawton-16	Room 308, Combination Sink, Bubbler	C	1:20 PM	5	1	N	First Draw, Filtered.
Lawton-17	Room 305, Combination Sink, Bubbler	C	1:26 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-18	Room 304, Combination Sink, Bubbler	C	1:29 PM	5	ND	N	First Draw, Filtered.
Lawton-19	Room 303, Combination Sink, Bubbler	C	1:33 PM	5	ND	N	First Draw, Filtered.
Lawton-20	Room 302, Combination Sink, Bubbler	C	1:36 PM	5	ND	N	First Draw, Filtered.
Lawton-21	Room 301, Combination Sink, Bubbler	C	1:39 PM	5	ND	N	First Draw, Filtered.
Lawton-22	Room 204, Combination Sink, Faucet	C	12:49 PM	5	ND	Y	First Draw, Filtered.
Lawton-23	Room 209, Combination Sink, Bubbler	C	1:05 PM	5	ND	N	First Draw, Filtered.
Lawton-24	Room 208, Combination Sink, Bubbler	C	1:02 PM	5	ND	N	First Draw, Filtered.
Lawton-25	Cafeteria, Hydration Station, Bottle Fill	BT	12:55 PM	5	ND	N	First Draw, Filtered.
Lawton-26	Cafeteria, Hydration Station, Water Cooler	BT	12:56 PM	5	ND	N	First Draw, Filtered.
Lawton-27	Room 311, Combination Sink, Bubbler	C	1:41 PM	5	1	N	First Draw, Filtered.
Lawton-28	Kitchen, Single Prep Sink	KF	12:59 PM	5	1	Y	First Draw, Filtered.
Lawton-29	Room 204, Combination Sink, Bubbler	C	12:50 PM	5	ND	N	First Draw, Filtered.
Lawton-30	Room 202, Combination Sink, Bubbler	C	12:41 PM	5	ND	N	First Draw, Filtered.
Lawton-31	Room 201, Combination Sink, Bubbler	C	12:28 PM	5	ND	N	First Draw, Filtered.
Lawton-32	Room 101, Combination Sink, Bubbler	C	12:22 PM	5	ND	N	First Draw, Filtered.
Lawton-33	Room 102, Combination Sink, Bubbler	C	12:14 PM	5	ND	N	First Draw, Filtered.
Lawton-34	Main Office, Kitchen Faucet	KF	12:12 PM	5	13	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-35	Hallway Outside Room 101, Hydration Station, Bottle Fill	BT	12:17 PM	5	ND	N	First Draw, Filtered.
Lawton-36	Hallway Outside Room 101, Hydration Station, Water Cooler	BT	12:18 PM	5	ND	N	First Draw, Filtered.
Lawton-37	Hallway Outside Room 114, Hydration Station, Bottle Fill	BT	1:14 PM	5	ND	N	First Draw, Filtered.
Lawton-38	Hallway Outside Room 114, Hydration Station, Water Cooler	BT	1:15 PM	5	ND	N	First Draw, Filtered.
Lawton-39	Room 209, Combination Sink, Faucet	C	1:06 PM	5	ND	Y	First Draw, Filtered.
Lawton-40	Room 109, Combination Sink, Bubbler	C	2:06 PM	5	ND	N	First Draw, Filtered.
Lawton-41	Room 108, Combination Sink, Bubbler	C	2:14 PM	5	ND	N	First Draw, Filtered.
Lawton-42	Room 107, Combination Sink, Bubbler	C	2:10 PM	5	ND	N	First Draw, Filtered.
Lawton-43	Room 106, Combination Sink, Bubbler	C	2:18 PM	5	ND	N	First Draw, Filtered.
Lawton-44	Room 310, Combination Sink, Faucet	C	1:18 PM	5	ND	Y	First Draw, Filtered.
Lawton-45	Room 316, Combination Sink, Faucet	C	2:02 PM	5	ND	Y	First Draw, Filtered.
Lawton-46	Room 308, Combination Sink, Faucet	C	1:21 PM	5	ND	Y	First Draw, Filtered.
Lawton-47	Room 311, Combination Sink, Faucet	C	1:30 PM	5	9	Y	First Draw, Filtered.
Lawton-48	Room 305, Combination Sink, Faucet	C	1:27 PM	5	ND	Y	First Draw, Filtered.
Lawton-49	Room 304, Combination Sink, Faucet	C	1:30 PM	5	ND	Y	First Draw, Filtered.
Lawton-50	Room 303, Combination Sink, Faucet	C	1:34 PM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-51	Room 302, Combination Sink, Faucet	C	1:37 PM	5	ND	Y	First Draw, Filtered.
Lawton-52	Room 301, Combination Sink, Faucet	C	1:40 PM	5	ND	Y	First Draw, Filtered.
Lawton-53	Room 109, Combination Sink, Faucet	C	2:07 PM	5	ND	Y	First Draw, Filtered.
Lawton-54	Room 108, Combination Sink, Faucet	C	2:15 PM	5	ND	Y	First Draw, Filtered.
Lawton-55	Room 107, Combination Sink, Faucet	C	2:17 PM	5	ND	Y	First Draw, Filtered.
Lawton-56	Room 106, Combination Sink, Faucet	C	2:19 PM	5	47	Y	First Draw, Filtered.
Lawton-57	Room 208, Combination Sink, Faucet	C	1:03 PM	5	ND	Y	First Draw, Filtered.
Lawton-58	Main Office, Nurses Single Sink, Faucet	F	12:10 PM	5	ND	Y	First Draw, Filtered.
Lawton-59	Room 102, Combination Sink, Faucet	C	12:15 PM	5	ND	Y	First Draw, Filtered.
Lawton-60	Room 101, Combination Sink, Faucet	C	12:23 PM	5	5	Y	First Draw, Filtered.
Lawton-61	Room 202, Combination Sink, Faucet	C	12:42 PM	5	3	Y	First Draw, Filtered.
Lawton-62	Room 203, Combination Sink, Faucet	C	12:45 PM	5	ND	Y	First Draw, Filtered.
Lawton-63	Room 101, Single Sink, Faucet	F		5			Location Not Currently Functional
Lawton-64	Room 201, Single Sink, Faucet	F	12:26 PM	5	ND	Y	First Draw, Filtered.
Lawton-65	Room 218, Combination Sink, Bubbler	C	12:38 PM	5	ND	N	First Draw, Filtered.
Lawton-66	Hallway Outside Room 301, Hydration Station, Bottle Fill	BT	1:24 PM	5	ND	N	First Draw, Filtered.
Lawton-67	Hallway Outside Room 301, Hydration Station, Water Cooler	BT	1:25 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/1/2020							
Sampler: Alec Staber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-68	Hallway Outside Room 312, Hydration Station, Water Cooler	BT	1:44 PM	5	ND	N	First Draw, Filtered.
Lawton-69	Hallway Outside Room 312, Hydration Station, Bottle Fill	BT	1:45 PM	5	ND	N	First Draw, Filtered.

Lawton Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Steven Ripley							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-63	Room 101, Single Sink, Faucet	F	8:55 AM	5	7	Y	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/15/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-15A	Room 313, Kitchen Faucet	KF	8:10 AM	5	ND ³	Y	Follow-up Flush, Filtered.
Lawton-47A	Room 311, Combination Sink, Faucet	C	8:00 AM	5	ND	Y	Follow-up Flush, Filtered.
Lawton-56A	Room 106, Combination Sink, Faucet	C	7:55 AM	5	ND	Y	Follow-up Flush, Filtered.

Lawton Elementary School							
Date of Sampling: 2/19/2020							
Sampler: Jenna Sendra							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-63A	Room 101, Single Sink, Faucet	F	5:53 PM	5	ND	Y	Follow-up Flush, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Lawton Elementary School							
Date of Sampling: 2/26/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-15B	Room 313, Kitchen Faucet	KF	7:50 AM	5	2	Y	First Follow-up First Draw Following Replacement
Lawton-34A	Main Office, Kitchen Faucet	KF	7:30 AM	5	23	Y	First Follow-up First Draw Following Replacement
Lawton-47B	Room 311, Combination Sink, Faucet	C	7:55 AM	5	6	Y	First Follow-up First Draw Following Replacement
Lawton-56B	Room 106, Combination Sink, Faucet	C	7:45 AM	5	19	Y	First Follow-up First Draw Following Replacement
Lawton-63B	Room 101, Single Sink, Faucet	F	7:39 AM	5	2	Y	First Follow-up First Draw Following Replacement

Lawton Elementary School							
Date of Sampling: 3/3/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-34B	Main Office, Kitchen Faucet	KF	6:44 AM	5	ND	Y	Second Follow-up First Draw Following Replacement
Lawton-47C	Room 311, Combination Sink, Faucet	C	6:56 AM	5	ND	Y	Second Follow-up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Lawton Elementary School							
Date of Sampling: 3/3/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-56C	Room 106, Combination Sink, Faucet	C	6:50 AM	5	ND	Y	Second Follow-up First Draw Following Replacement

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested