



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Pattengill Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-01	Teacher's Lounge, Kitchen Sink	KF	8:40 AM	5	ND ³	Y	First Draw, Filtered.
Pattengill-02	Room C-4, Combination Sink, Faucet	C	11:45 AM	5	ND	Y	First Draw, Filtered.
Pattengill-03	Hallway, Outside Room C-8, Hydration Station, Water Cooler	BT	12:05 PM	5	ND	N	First Draw, Filtered.
Pattengill-04	Hallway, Outside Room A-1, Hydration Station, Water Cooler	BT	10:25 AM	5	ND	N	First Draw, Filtered.
Pattengill-05	Room A-4, Combination Sink, Bubbler			5			Location Not Currently Functional
Pattengill-06	Room A-6, Combination Sink, Faucet	C	11:00 AM	5	ND	Y	First Draw, Filtered.
Pattengill-07	Room A-8, Combination Sink, Faucet	C	10:40 AM	5	ND	Y	First Draw, Filtered.
Pattengill-08	Room A-8, Combination Sink, Bubbler	C	10:40 AM	5	ND	N	First Draw, Filtered.
Pattengill-09	Room A-7, Combination Sink, Bubbler	C	10:55 AM	5	ND	N	First Draw, Filtered.
Pattengill-10	Room B-16, Combination Sink, Faucet	C	10:05 AM	5	ND	Y	First Draw, Filtered.
Pattengill-11	Room B-7, Combination Sink, Faucet	C	9:30 AM	5	ND	Y	First Draw, Filtered.
Pattengill-12	Hallway, Outside Room B-3, Hydration Station, Water Cooler	BT	9:00 AM	5	ND	Y	First Draw, Filtered.
Pattengill-13	Media Center Kitchen, Faucet	KF	12:10 PM	5	ND	Y	First Draw, Filtered.
Pattengill-14	Hallway, Outside Room C-8, Hydration Station, Bottle Fill	BT	12:05 PM	5	ND	N	First Draw, Filtered.
Pattengill-15	Hallway, Outside Room A-1, Hydration Station, Bottle Fill	BT	10:25 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Pattengill Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-16	Cafeteria Kitchen, 3-Compartment, Add On Single Far Left Faucet	KF	12:00 PM	5	ND	Y	First Draw, Filtered.
Pattengill-17	Hallway, Outside Room C-4, Combination Sink, Bubbler	C	11:35 AM	5	ND	N	First Draw, Filtered.
Pattengill-18	Hallway, Outside Room C-4, Combination Sink, Faucet	C	11:35 AM	5	4	Y	First Draw, Filtered.
Pattengill-19	Room C-4, Combination Sink, Bubbler	C	11:45 AM	5	ND	N	First Draw, Filtered.
Pattengill-20	Hallway, Outside Room B-3, Hydration Station, Bottle Fill	BT	9:00 AM	5	ND	Y	First Draw, Filtered.
Pattengill-21	OPEN NUMBER			5			
Pattengill-22	Room B-3, Combination Sink, Bubbler	C	8:45 AM	5	ND	N	First Draw, Filtered.
Pattengill-23	Room B-3, Combination Sink, Faucet	C	8:45 AM	5	ND	Y	First Draw, Filtered.
Pattengill-24	Room B-4, Combination Sink, Bubbler	C	9:05 AM	5	ND	N	First Draw, Filtered.
Pattengill-25	Room B-4, Combination Sink, Faucet	C	9:05 AM	5	ND	Y	First Draw, Filtered.
Pattengill-26	Room B-5, Combination Sink, Bubbler	C	9:10 AM	5	ND	N	First Draw, Filtered.
Pattengill-27	Room B-5, Combination Sink, Faucet	C	9:10 AM	5	1	Y	First Draw, Filtered.
Pattengill-28	Room B-6, Combination Sink, Bubbler	C	9:15 AM	5	ND	N	First Draw, Filtered.
Pattengill-29	Room B-6, Combination Sink, Faucet	C	9:15 AM	5	1	Y	First Draw, Filtered.
Pattengill-30	Room B-7, Combination Sink, Bubbler	C	9:30 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Pattengill Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-31	Room B-8, Combination Sink, Bubblers	C	9:40 AM	5	ND	N	First Draw, Filtered.
Pattengill-32	Room B-8, Combination Sink, Faucet	C	9:40 AM	5	ND	Y	First Draw, Filtered.
Pattengill-33	Room B-9, Combination Sink, Bubblers	C	9:45 AM	5	ND	N	First Draw, Filtered.
Pattengill-34	Room B-9, Combination Sink, Faucet	C	9:45 AM	5	ND	Y	First Draw, Filtered.
Pattengill-35	Room B-11, Combination Sink, Bubblers	C	9:50 AM	5	ND	N	First Draw, Filtered.
Pattengill-36	Room B-11, Combination Sink, Faucet	C	9:50 AM	5	ND	Y	First Draw, Filtered.
Pattengill-37	Room B-12, Combination Sink, Bubblers	C	9:55 AM	5	ND	N	First Draw, Filtered.
Pattengill-38	Room B-12, Combination Sink, Faucet	C	9:55 AM	5	ND	Y	First Draw, Filtered.
Pattengill-39	Room B-16, Combination Sink, Bubblers	C	10:05 AM	5	ND	N	First Draw, Filtered.
Pattengill-40	Room B-17, Combination Sink, Bubblers	C	10:10 AM	5	ND	N	First Draw, Filtered.
Pattengill-41	Room B-17, Combination Sink, Faucet	C	10:10 AM	5	ND	Y	First Draw, Filtered.
Pattengill-42	Room B-18, Combination Sink, Bubblers	C	10:15 AM	5	ND	N	First Draw, Filtered.
Pattengill-43	Room B-18, Combination Sink, Faucet	C	10:15 AM	5	ND	Y	First Draw, Filtered.
Pattengill-44	Room A-2, Combination Sink, Bubblers	C	11:30 AM	5	ND	N	First Draw, Filtered.
Pattengill-45	Room A-2, Combination Sink, Faucet	C	11:30 AM	5	1	Y	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Pattengill Elementary School							
Date of Sampling: 1/11/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-46	Room A-3, Combination Sink, Bubbler	C	11:25 AM	5	ND	N	First Draw, Filtered.
Pattengill-47	Room A-3, Combination Sink, Faucet	C	11:25 AM	5	ND	Y	First Draw, Filtered.
Pattengill-48	Room A-4, Combination Sink, Faucet	C		5			Location Not Currently Functional
Pattengill-49	Room A-5, Single Sink Faucet	F	11:05 AM	5	ND	Y	First Draw, Filtered.
Pattengill-50	Room A-6, Combination Sink, Bubbler	C	11:00 AM	5	ND	N	First Draw, Filtered.
Pattengill-51	Room A-7, Combination Sink, Faucet	C	10:55 AM	5	ND	Y	First Draw, Filtered.
Pattengill-52	Room A-9, Combination Sink, Bubbler	C	10:35 AM	5	ND	N	First Draw, Filtered.
Pattengill-53	Room A-9, Combination Sink, Faucet	C	10:35 AM	5	ND	Y	First Draw, Filtered.
Pattengill-54	Hallway, Outside Room A-7, Hydration Station, Water Cooler	BT	10:50 AM	5	ND	N	First Draw, Filtered.
Pattengill-55	Hallway, Outside Room A-7, Hydration Station, Bottle Fill	BT	10:50 AM	5	ND	Y	First Draw, Filtered.
Pattengill-56	Hallway, Outside Room B-7, Hydration Station, Water Cooler	BT	9:20 AM	5	ND	N	First Draw, Filtered.
Pattengill-57	Hallway, Outside Room B-7, Hydration Station, Bottle Fill	BT		5			Location Not Currently Functional

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030

Pattengill Elementary School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-05	Room A-4, Combination Sink, Bubbler	C	1:36 PM	5	1	N	First Draw, Filtered. Previously Not Functional.
Pattengill-48	Room A-4, Combination Sink, Faucet	C	1:38 PM	5	5	Y	First Draw, Filtered. Previously Not Functional.
Pattengill-57	Hallway, Outside Room B-7, Hydration Station, Bottle Fill	BT	1:28 PM	5	ND	N	First Draw, Filtered. Previously Not Functional.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested