



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Scarlett Middle School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-01	Hallway, Adjacent to Band Room 138 & Stage, Hydration Station, Water Cooler	BT	10:22 AM	5	ND <sup>3</sup>	N	First Draw, Filtered.
Scarlett-02	Girl's Locker Room, Bubblers	B	10:00 AM	5	ND	N	First Draw, Filtered.
Scarlett-03	Boy's Locker Room, Bubblers	B	12:20 PM	5	ND	N	First Draw, Filtered.
Scarlett-04	Pool, Glass Fill, Outside Girls Locker Room	BT	10:12 AM	5	ND	N	First Draw, Filtered.
Scarlett-05	Kitchen, 3-Compartment Sink, Add on Faucet, Center	KF	9:55 AM	5	ND	Y	First Draw, Filtered.
Scarlett-06	Gym, Single Bubblers	B		5			Unable to Sample, Location in Use at Time of Sampling.
Scarlett-07	Pool, Bubblers, Outside Girls Locker Room	B	10:05 AM	5	ND	N	First Draw, Filtered.
Scarlett-08	Pool, Bubblers, Outside Boys Locker Room	B	10:07 AM	5	ND	N	First Draw, Filtered.
Scarlett-09	Staff Kitchen Faucet in Cafeteria	KF	12:06 PM	5	2	Y	First Draw, Filtered.
Scarlett-10	Hallway, Outside Main Office by Stairway, Single Water Cooler	WC	9:36 AM	5	ND	N	First Draw, Filtered.
Scarlett-11	OPEN NUMBER			5			
Scarlett-12	Hallway, Outside Room 130, Hydration Station, Water cooler	BT	10:33 AM	5	ND	N	First Draw, Filtered.
Scarlett-13	Hallway, Outside of Room 124, Hydration Station, Water Cooler	BT	10:22 AM	5	ND	N	First Draw, Filtered.
Scarlett-14	Room 137, Faucet	F	10:46 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Scarlett Middle School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-15	Hallway, Adjacent to Band Room 138 & Stage, Hydration Station, Bottle Fill	BT		5			Location Not Functional.
Scarlett-16	Hallway, Outside Room 215, Hydration Station, Bottle Fill	BT	11:04 AM	5	ND	N	First Draw, Filtered.
Scarlett-17	Room 201, Faucet	F	11:34 AM	5	ND	Y	First Draw, Filtered.
Scarlett-18	Room 228, Faucet	F	11:30 AM	5	4	Y	First Draw, Filtered.
Scarlett-19	Hallway, Outside of Room 228, Hydration Station, Bottle Fill	BT	11:38 AM	5	ND	N	First Draw, Filtered.
Scarlett-20	Hallway, Outside of Room 228, Hydration Station, Water Cooler	BT	11:40 AM	5	ND	N	First Draw, Filtered.
Scarlett-21	Auxiliary Gym, Hydration Station, Water Cooler	BT	11:54 AM	5	ND	N	First Draw, Filtered.
Scarlett-22	Hallway, Outside Room 144, Hydration Station, Bottle Fill	BT	9:38 AM	5	ND	N	First Draw, Filtered.
Scarlett-23	Hallway, Outside Room 144, Hydration Station, Water Cooler	BT	9:40 AM	5	ND	N	First Draw, Filtered.
Scarlett-24	Cafeteria, Hydration Station, Water Cooler	BT	12:26 PM	5	ND	N	First Draw, Filtered.
Scarlett-25	Cafeteria, Hydration Station, Bottle Fill	BT	12:27 PM	5	ND	N	First Draw, Filtered.
Scarlett-26	Cafeteria, Single Water Cooler	WC	12:28 PM	5	ND	N	First Draw, Filtered.
Scarlett-27	Hallway, Outside of Room 124, Hydration Station, Bottle Fill	BT	10:48 AM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubblers, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Scarlett Middle School							
Date of Sampling: 2/8/2020							
Sampler: Amanda Peterson							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-28	Hallway, Outside Room 215, Hydration Station, Water Cooler	BT	11:00 AM	5	ND	N	First Draw, Filtered.
Scarlett-29	Hallway, Outside of Gym, Hydration Station, Bottle Fill	BT		5		N	Unable to Sample, Location in Use at Time of Sampling.
Scarlett-30	Hallway, Outside Gym, Hydration Station, Water Cooler	BT		5		N	Unable to Sample, Location in Use at Time of Sampling.
Scarlett-31	Hallway, Outside Room 205, Hydration Station, Water Cooler	BT	10:52 AM	5	ND	N	First Draw, Filtered.
Scarlett-32	Pool, Glass Fill, Outside Boys Locker Room	BT	10:10 AM	5	5	N	First Draw, Filtered.
Scarlett-33	Hallway, Outside Room 130, Hydration Station, Bottle Fill	BT	10:35 AM	5	ND	N	First Draw, Filtered.
Scarlett-34	Mail Room #A111, Single Sink, Faucet	F	9:30 AM	5	ND	Y	First Draw, Filtered.
Scarlett-35	Auxiliary Gym, Hydration Station, Bottle Fill	BT	11:56 AM	5	ND	N	First Draw, Filtered.
Scarlett-36	RAHS Clinic Office, Single Sink, Faucet	F		5		N	Location Not Functional.
Scarlett-37	Kitchen Area, Kitchen Kettle	KK	12:13 PM	5	320	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Scarlett Middle School							
Date of Sampling: 2/15/2020							
Sampler: Lindsey Eveleth							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-06	Gym, Single Bubbler	B	7:01 AM	5	ND	N	First Draw, Filtered.
Scarlett-15	Hallway, Adjacent to Band Room 138 and Stage, Hydration Station, Bottle Fill	BT	7:07 AM	5	ND	N	First Draw, Filtered.
Scarlett-29	Hallway, Outside of Gym, Hydration Station, Bottle Fill	BT	6:50 AM	5	ND	N	First Draw, Filtered.
Scarlett-30	Hallway, Outside of Gym, Hydration Station, Water Cooler	BT	6:52 AM	5	ND	N	First Draw, Filtered.
Scarlett-36	RAHS Clinic Office, Single Sink, Faucet	F	7:20 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE190030**

Scarlett Middle School							
Date of Sampling: 2/22/2020							
Sampler: Alex Reiber							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-37A	Kitchen Area, Kitchen Kettle	KK	6:00 PM	5	21	Y	Repeat First Draw, Filtered.

Scarlett Middle School							
Date of Sampling: 2/29/2020							
Sampler: Carly Doulos							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-37B	Kitchen Area, Kitchen Kettle	KK	1:42 PM	5	ND	N	Follow-Up First Draw Following Replacement, Filtered

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee  
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>  
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L  
 4) NT = Not Tested