



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-01	Room C112, Single Sink, Faucet	F	8:14 AM	5	ND ³	Y	First Draw, Filtered.
PFC-02	Room A102, Combination Sink, Bubbler	C	10:21 AM	5	ND	N	First Draw, Filtered.
PFC-03	Room A100, Combination Sink, Bubbler	C	10:08 AM	5	ND	N	First Draw, Filtered.
PFC-04	Room B102, Combination Sink, Bubbler	C	11:50 AM	5	ND	N	First Draw, Filtered.
PFC-05	Room B105, Combination Sink, Bubbler	C	12:13 PM	5	ND	N	First Draw, Filtered.
PFC-06	Family Room E100, 2-Compartment Sink, Faucet	F	9:25 AM	5	ND	Y	First Draw, Filtered.
PFC-07	Room A108, Combination Sink, Bubbler			5			Classroom not Currently in Use, Outlet Turned Off.
PFC-08	Room C102, Single Sink, Faucet	F	12:59 PM	5	2	N	First Draw, Filtered.
PFC-09	Room A108, Combination Sink, Faucet			5			Classroom not Currently in Use, Outlet Turned Off.
PFC-10	Room D100, Combination Sink, Bubbler	C	9:16 AM	5	1	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-11	Room D100, Combination Sink, Faucet	C	9:17 AM	5	3	Y	First Draw, Filtered.
PFC-12	Room D102, Combination Sink, Bubbler	C	9:01 AM	5	ND	N	First Draw, Filtered.
PFC-13	Kitchen, 3-Compartment Sink, Middle Faucet	KF	12:32 PM	5	2	Y	First Draw, Filtered.
PFC-14	OPEN NUMBER			5			
PFC-15	Hallway Outside Room D109, Hydration Station, Bottle Fill	BT	8:00 AM	5	ND	N	First Draw, Filtered.
PFC-16	Room C105, Single Sink, Faucet	F	12:39 PM	5	1	Y	First Draw, Filtered.
PFC-17	Room C105, Combination Sink, Bubbler	C	12:40 PM	5	ND	N	First Draw, Filtered.
PFC-18	Room C105, Combination Sink, Faucet	C	12:41 PM	5	2	Y	First Draw, Filtered.
PFC-19	Room C103, Single Sink, Faucet	C	12:53 PM	5	4	Y	First Draw, Filtered.
PFC-20	Room C103, Combination Sink, Faucet	C	12:54 PM	5	ND	Y	First Draw, Filtered.
PFC-21	Room C103, Combination Sink, Bubbler	C	12:55 PM	5	ND	N	First Draw, Filtered.
PFC-22	Room C102, Combination Sink, Faucet	C	1:01 PM	5	ND	Y	First Draw, Filtered.
PFC-23	Room C102, Combination Sink, Bubbler	C	1:02 PM	5	ND	N	First Draw, Filtered.
PFC-24	Room C100, Single Sink, Faucet	F	1:12 PM	5	ND	Y	First Draw, Filtered.
PFC-25	Room C100, Combination Sink, Bubbler	C	1:13 PM	5	ND	N	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-26	Room C100, Combination Sink, Faucet	C	1:14 PM	5	ND	Y	First Draw, Filtered.
PFC-27	Room C112, Combination Sink, Bubbler	C	8:16 AM	5	ND	N	First Draw, Filtered.
PFC-28	Room C112, Combination Sink, Faucet	C	8:17 AM	5	ND	Y	First Draw, Filtered.
PFC-29	Hallway Outside Room D109, Hydration Station, Water Cooler	BT	8:01 AM	5	ND	N	First Draw, Filtered.
PFC-30	Room D104, Single Sink, Faucet	F	8:34 AM	5	ND	Y	First Draw, Filtered.
PFC-31	Room D104, Combination Sink, Bubbler	C	8:35 AM	5	ND	N	First Draw, Filtered.
PFC-32	Room D104, Combination Sink, Faucet	C	8:36 AM	5	2	Y	First Draw, Filtered.
PFC-33	Room D103, Single Sink, Faucet	F	8:50 AM	5	62	Y	First Draw, Filtered.
PFC-34	Room D103, Combination Sink, Bubbler	C	8:51 AM	5	3	N	First Draw, Filtered.
PFC-35	Room D103, Combination Sink, Faucet	C	8:52 AM	5	2	Y	First Draw, Filtered.
PFC-36	Room D102, Combination Sink, Faucet	C	9:02 AM	5	ND	Y	First Draw, Filtered.
PFC-37	Room D102, Single Sink, Faucet	F	9:03 AM	5	ND	Y	First Draw, Filtered.
PFC-38	Room D100, Single Sink, Faucet	F	9:18 AM	5	ND	Y	First Draw, Filtered.
PFC-39	Room E105, Kitchen Sink, Faucet	KF	9:46 AM	5	ND	N	First Draw, Filtered.
PFC-40	Room E100, Left Faucet	F	9:54 AM	5	1	Y	First Draw, Filtered.
PFC-41	Room E100, Right Faucet	F	9:55 AM	5	2	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-42	Room B100, Combination Sink, Faucet	C	11:39 AM	5	2	Y	First Draw, Filtered.
PFC-43	Room B100, Combination Sink, Bubbler	C	11:40 AM	5	ND	N	First Draw, Filtered.
PFC-44	Room B100, Single Sink, Faucet	F	11:41 AM	5	ND	N	First Draw, Filtered.
PFC-45	Room B102, Single Sink, Faucet	F	11:52 AM	5	79	Y	First Draw, Filtered.
PFC-46	Room B102, Combination Sink, Faucet	C	11:53 AM	5	ND	Y	First Draw, Filtered.
PFC-47	Room B103, Single Sink, Faucet	F	11:59 AM	5	ND	N	First Draw, Filtered.
PFC-48	Room B103, Combination Sink, Bubbler	C	12:00 PM	5	ND	N	First Draw, Filtered.
PFC-49	Room B103, Combination Sink, Faucet	C	12:01 PM	5	ND	Y	First Draw, Filtered.
PFC-50	Room B105, Combination Sink, Faucet	C	12:14 PM	5	ND	Y	First Draw, Filtered.
PFC-51	Room B105, Single Sink, Faucet	F	12:15 PM	5	ND	N	First Draw, Filtered.
PFC-52	Room A105, Combination Sink, Faucet	C	10:51 AM	5	2	Y	First Draw, Filtered.
PFC-53	Room A105, Combination Sink, Bubbler	C	10:52 AM	5	ND	N	First Draw, Filtered.
PFC-54	Room A105, Single Sink, Faucet	F	10:53 AM	5	ND	Y	First Draw, Filtered.
PFC-55	Room A103, Single Sink, Faucet	F	10:33 AM	5	ND	Y	First Draw, Filtered.
PFC-56	Room A103, Combination Sink, Faucet	C	10:34 AM	5	ND	Y	First Draw, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-57	Room A103, Combination Sink, Bubbler	C	10:35 AM	5	ND	N	First Draw, Filtered.
PFC-58	Room A102, Single Sink, Faucet	F	10:25 AM	5	ND	Y	First Draw, Filtered.
PFC-59	Room A102, Combination Sink, Faucet	C	10:26 AM	5	2	Y	First Draw, Filtered.
PFC-60	Room A100, Single Sink, Faucet	F	10:10 AM	5	ND	Y	First Draw, Filtered.
PFC-61	Room A100, Combination Sink, Faucet	C	10:11 AM	5	ND	Y	First Draw, Filtered.
PFC-62	Room A107, Right Faucet	F	10:59 AM	5	7	Y	First Draw.
PFC-63	Room A107, Left Faucet	F	11:00 AM	5	1	Y	First Draw.
PFC-64	Hallway Outside Room B112, Single Water Cooler	WC	11:31 AM	5	ND	N	First Draw, Filtered.
PFC-65	Hallway Outside Room B112, Hydration Station, Bottle Fill	BT	11:32 AM	5	ND	N	First Draw, Filtered.
PFC-66	Hallway Outside Room B112, Hydration Station, Water Cooler	BT	11:33 AM	5	ND	N	First Draw, Filtered.
PFC-67	Room A108, Right Single Sink, Faucet			5			Outlet Not Currently in Use, Turned Off.
PFC-68	Room E100, Hydration Station, Bottle Fill	BT	9:56 AM	5	ND	N	First Draw, Filtered.
PFC-69	Room E100, Hydration Station, Water Cooler	BT	9:57 AM	5	ND	N	First Draw, Filtered.
PFC-70	OPEN NUMBER			5			

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-71	OPEN NUMBER			5			
PFC-72	OPEN NUMBER			5			
PFC-73	OPEN NUMBER			5			
PFC-74	OPEN NUMBER			5			
PFC-75	OPEN NUMBER			5			
PFC-76	Classroom C105 and C103 Bathroom, Left Faucet	F	12:45 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-77	Classroom C105 and C103 Bathroom, Middle Faucet	F	12:46 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-78	Classroom C105 and C103 Bathroom, Right Faucet	F	12:47 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-79	Classroom C102 and C100 Bathroom, Left Faucet	F	1:06 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-80	Classroom C102 and C100 Bathroom, Middle Faucet	F	1:07 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-81	Classroom C102 and C100 Bathroom, Right Faucet	F	1:08 PM	5	3	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-82	Classroom D100 and D102 Bathroom, Left Faucet	F	9:07 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-83	Classroom D100 and D102 Bathroom, Middle Faucet	F	9:08 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-84	Classroom D100 and D102 Bathroom, Right Faucet	F	9:09 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-85	Classroom D104 and D103 Bathroom, Left Faucet	F	8:41 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-86	Classroom D104 and D103 Bathroom, Middle Faucet	F	8:42 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-87	Classroom D104 and D103 Bathroom, Right Faucet	F	8:43 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-88	Classroom D107 Bathroom, Left Faucet	F	8:24 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-89	Classroom D107 Bathroom, Right Faucet	F	8:25 AM	5	3	Y	First Draw, Filtered.
PFC-90	OPEN NUMBER			5			
PFC-91	OPEN NUMBER			5			
PFC-92	OPEN NUMBER			5			
PFC-93	Clinic Room E102 Bathroom, Left Faucet	F	9:39 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Drinking.
PFC-94	OPEN NUMBER			5			
PFC-95	Classroom A100 and A102 Bathroom, Left Faucet	F	10:14 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-96	Classroom A100 and A102 Bathroom, Middle Faucet	F	10:15 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-97	Classroom A100 and A102 Bathroom, Right Faucet	F	10:16 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-98	Classroom A103 and A105 Bathroom, Left Faucet	F	10:41 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-99	Classroom A103 and A105 Bathroom, Middle Faucet	F	10:42 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-100	Classroom A103 and A105 Bathroom, Right Faucet	F	10:43 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-101	OPEN NUMBER			5			
PFC-102	OPEN NUMBER			5			
PFC-103	OPEN NUMBER			5			
PFC-104	OPEN NUMBER			5			
PFC-105	OPEN NUMBER			5			
PFC-106	OPEN NUMBER			5			
PFC-107	OPEN NUMBER			5			
PFC-108	Classroom B100 and B102 Bathroom, Left Faucet	F	11:44 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/14/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-109	Classroom B100 and B102 Bathroom, Middle Faucet	F	11:45 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-110	Classroom B100 and B102 Bathroom, Right Faucet	F	11:46 AM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-111	Classroom B105 and B103 Bathroom, Left Faucet	F	12:04 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-112	Classroom B105 and B103 Bathroom, Middle Faucet	F	12:05 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.
PFC-113	Classroom B105 and B103 Bathroom, Right Faucet	F	12:06 PM	5	ND	Y	First Draw, Filtered, Bathroom Faucet Used for Teeth Brushing.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE190030**

Westerman Preschool							
Date of Sampling: 12/27/2019							
Sampler: Kellie Das							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-33A	Room D103, Single Sink, Faucet	F	9:16 AM	5	3	Y	Follow-up First Draw Following Replacement, Filtered.
PFC-62	Room A107, Right Faucet	F	N/A	5	N/A	Y	Identified as an Area of Infrequent Use, Designated as a Non-Potable Water Source.

Westerman Preschool							
Date of Sampling: 1/3/2020							
Sampler: Alex Reiber							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
PFC-45A	Room B102, Single Sink, Faucet	F	2:40 PM	5	3	Y	Follow-up First Draw Following Replacement, Filtered.

1) Type: B = Bubbler, BT = Bottle Fill/Cooler, WC = Water Cooler, C = Combination Sink, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested